



**SUMMIT Engineering, Laboratory and Testing, PC (SUMMIT)**  
3575 Centre Circle  
Fort Mill, South Carolina 29715  
[www.summit-companies.com](http://www.summit-companies.com)  
Phone: (704) 504-1717  
Fax: (704) 504-1125

May 10, 2017

**Subject: Asbestos Clearance Air Monitoring Report**  
16601 Old Statesville Road, Huntersville, NC  
SUMMIT Project No. 4487.500

SUMMIT ENGINEERING, LABORATORY AND TESTING, PC (SUMMIT) performed asbestos air monitoring for the removal of non-friable floor tile and mastic in the structure located at 16601 Old Statesville Road, Huntersville, NC. The asbestos abatement was performed by Superior Abatement. Daily air monitoring was performed on May 9, 2017. SUMMIT performed one set of final PCM Clearance sampling after the abatement and fine cleaning was completed on May 9, 2017. Daily, and Clearance air monitoring was performed by Phase Contrast Microscopy (PCM). Daily, and Clearance PCM samples were analyzed by Summit Laboratories, LLC, in Charlotte, NC. SUMMIT's **AIHA Proficiency Analytical Testing Program (PAT) Laboratory Number is 220241.**

The PCM Clearance results are below EPA, OSHA and NCDHHS clearance requirements. The area is ready for re-occupation and/or demolition.

If you have any questions regarding our assessment of the subject property or our conclusions, please do not hesitate to call us at (704) 504-1717.

**SUMMIT**

Richard M. Wyche  
Environmental Technician  
NC DHHS Air Monitor No. 80907  
Expiration Date: September 30, 2017  
NC DHHS AHERA Asbestos Inspector No. BI-01478  
Expiration Date: September 30, 2017

Attachments:

Daily Air Monitoring Report  
Clearance Air Monitoring Report

<b>SUMMIT ELT, Inc.</b> <b>3575 Centre Circle</b> <b>Fort Mill, SC 29715</b> <b>704-504-1717</b> <a href="http://www.summit-companies.com">www.summit-companies.com</a> Air Monitoring Form		Air Monitor: Richard Wyche		Date: 5/9/2017					
		License No. NC DHHS Air Monitor #80907		Day: 5					
		Analyst: Richard Wyche AIHA PAT Lab Number 220241		Project: 16601 Old Statesville Road					
				Location: 16601 Old Statesville Road, Huntersville, NC					
				Client: SK Goodman					
				Project No. 4487.500					
1: Inside Building		22 mm cassette: X	PCM: X	Blank No.	2017-05-09-BL-D1		Dailies		
2: Outside Building									
3: Inside Work Area		37 mm cassette:	TEM:	Fibers / Field:	0/100				
4: Outside Work Area									
Sample #	Area	Pump	Name /Location	Flow Rate (LPM):	Start Time	Stop Time	Volume	Fibers/Field	f/cc
2017-05-09-4487-A 1-D1	1 / 4	1	Dailies – Area 1	8	1240	1510	1200 L	4/100	0.002
2017-05-09-4487-A 2-D1	1 / 4	2	Dailies – Area 2	8	1240	1510	1200 L	6/100	0.002
2017-05-09-4487-EX-D1	2 / 4	3	Dailies – Exhaust	8	1240	1510	1200 L	5.5/100	0.002
2017-05-09-4487-WLO-D1	2 / 4	4	Dailies - Loadout	8	1240	1510	1200 L	4.5/100	0.002
One set of PCM Daily samples were run during abatement of non-friable floor tile and mastic in the structure located at 16601 Old Statesville Rd., Huntersville, NC.									

<b>SUMMIT ELT, P.C.</b> <b>3575 Centre Circle</b> <b>Fort Mill, SC 29715</b> <b>704-504-1717</b> <a href="http://www.summit-companies.com">www.summit-companies.com</a> Air Monitoring Form			Air Monitor: Richard Wyche		Date: 5/9/2017				
			License No. NC DHHS Air Monitor #80907		Day: 5				
			Analyst: Richard Wyche AIHA PAT Lab Number 220241		Project: 16601 Old Statesville Road				
					Location: 16601 Old Statesville Road, Huntersville, NC 28078				
1: Inside Building			25 mm cassette: X	PCM: X	Blank No.	2017-05-09-4487- BLK			
2: Outside Building									
3: Inside Work Area			37 mm cassette:	TEM:	Fibers / Field:	0/100			
4: Outside Work Area									
Sample #	Area	Pump	Name/SSN/Location	Flow Rate (LPM):	Start Time	Stop Time	Volume	Fibers/Field	f/cc
2017-05-09-4487-C-1	1/3	1	Clearance – 1	16	1715	1830	1200	7/100	0.003
2017-05-09-4487-C-2	1/3	2	Clearance – 2	16	1715	1830	1200	7.5/100	0.003
2017-05-09-4487-C-3	1/3	3	Clearance – 3	16	1715	1830	1200	4.5/100	0.002
2017-05-09-4487-C-4	1/3	4	Clearance – 4	16	1715	1830	1200	5/100	0.002
2017-05-09-4487-C-5	1/3	5	Clearance – 5	16	1715	1830	1200	6/100	0.002
2017-05-09-4487-C-B					PM	PM		0/100	
PCM Clearance samples were ran in the area of abatement of non-friable floor tile and mastic in the structure located at 16601 Old Statesville Road in Huntersville, NC.									