



**LEGEND**

- SIDEWALL ADJUSTABLE REGISTER
- CEILING 2'X2' LAY IN DIFFUSER
- CEILING EGGRATE RETURN
- UNIT HEATER
- FIRE DAMPER (FD)
- INSULATED DUCT
- TRANSFER GRILLE
- THERMOSTAT
- OPENING ABOVE CEILING
- ROOF HATCH

**NOTES:**

- ALL DUCTWORK TO HAVE MAXIMUM 6' OF FLEX TO DIFFUSERS
- LINE RETURN DROP FIRST 6'

**HARRIS ENVIRONMENTAL SYSTEMS**  
 11 CONNECTOR ROAD  
 ANDOVER, MASSACHUSETTS 01810  
 TEL. (603) 476-0100

**TITLE/SYSTEM**  
 MECHANICAL DUCT LAYOUT  
 (MEZZANINE)

**CUSTOMER**  
 NEW BOSTON SEAFOOD

**PROJECT**  
 BUILDING 1

2	SB	AS BUILT	1/5/98
1	CJ	RESUBMIT	04/07/97
1	CH	ISSUED FOR PERMIT	01/27/97
1	CH	ISSUED FOR PERMIT	01/27/97
1	CH	ISSUED FOR PERMIT	01/27/97
1	CH	ISSUED FOR PERMIT	01/27/97
1	CH	ISSUED FOR PERMIT	01/27/97
1	CH	ISSUED FOR PERMIT	01/27/97
1	CH	ISSUED FOR PERMIT	01/27/97
1	CH	ISSUED FOR PERMIT	01/27/97