

THE OFFICES AT
 MASON CREEK
 CORPORATE

 BLDG. #300,
 KATY, TX 77449

DATE OF ISSUE

PHASE	ISSUED FOR	DATE
FIRST DRAFT	CHECK SET	10/06/2020

 NOT FOR
 CONSTRUCTION
 FOR INFORMATION
 PURPOSES ONLY

These drawings and specifications are copyrighted. They are and shall remain the sole property of Purser Architectural, Inc. ("Architect") unless otherwise noted. These drawings are not to be used on other projects or extensions to this project except by agreement with appropriate compensation to Purser Architectural, Inc. Contractor is responsible for confirming and correlating dimensions at job site. Architect will not be responsible for construction means, methods, techniques or procedures or for safety precautions and programs in connection with the project. Reproduction of these drawings is prohibited without written permission from Purser Architectural, Inc. These drawings are not valid for construction purposes without seal and signature from licensed architect.

 PROJECT NUMBER
 D.19.002.GINTER.03
 COPYRIGHT 2020 PURSER ARCHITECTURAL
 ALL RIGHTS RESERVED.

DATE: 10/09/2020

SHEET NUMBER:

A04.1

GENERAL NOTES		LEGEND	CODED NOTES
<p>Fire Walls: 1. Horizontal continuity. Fire walls shall be continuous from exterior wall to exterior wall and shall extend at least 18 inches beyond the exterior surface of exterior walls. -Exceptions: 1. Fire walls shall be permitted to terminate at the interior surface of combustible exterior sheathing or siding provided the exterior wall has fire-resistance rating of at least 1 hour from a horizontal distance of at least 4 feet on both sides of the fire wall. Openings within such exterior walls shall be protected by fire assemblies having a fire protection rating of not less than 3/4 hour. 2. Fire walls shall be permitted to terminate at the interior surface of noncombustible exterior sheathing, exterior siding or other noncombustible exterior finishes provided the sheathing, siding, or other exterior noncombustible finish extend a horizontal distance of at least 4 feet on both sides of the fire wall.</p> <p>4.2.5* Forward Reach: If the clear floor space only allows forward approach to an object, the maximum high forward reach allowed shall be 48 in. (see Fig. 5(a)). The minimum low forward reach is 15 in. If the high forward reach is over an obstruction, reach and clearances shall be as shown in Fig. 5 (b).</p> <p>4.2.6* Side Reach: If the clear floor space allows parallel approach by a person in a wheelchair, the maximum high side reach allowed shall be 54 in. and the low side reach shall be no less than 9 in. above the floor (Fig. 6(a) and 6(b)). If the side reach is over an obstruction, the reach and clearances shall be as shown in Fig. 6(c).</p> <p>All dimensions are to face of stud and columns</p>	 PROPOSED NEW WALL  ① DOOR SCHEDULE, RE: A08  ② WINDOW SCHEDULE, RE: A08	 ① ATTIC ACCESS, DISP. STAIRS  ② CLASS "A" FIRE EXTINGUISHER	

