

PO BOX 856
ANKENY, IOWA 50021

DEREK TEMPLE
515.778.2601

901 Thomas Beck Rd. Suite 301
Des Moines, IA 50315
515.276.4454
www.connect-arch.com
info@connect-arch.com

CONSULTANTS

ISSUES

[illegible]

DATE PRINTED: 11/7/2019

PROJECT NO: 1919

COPYRIGHT:

NECT Architecture & Design, P.C. holds all rights of copyright and to these prints, drawings and documents. No reproduction, copying, alteration, modification, usage, incorporation into other documents, or assignment of the same may occur without our prior written permission.

Copyright 2019 - CONNECT Architecture & Design, P.C.

MEET TITLE:

FLOOR PLAN

A1

SHEET 2

DF 4



1. FIELD VERIFY ALL DIMENSIONS.
2. ALL DIMENSIONS ARE TO CENTER OF OF WALL AND GRIDLINE U.N.O.
3. DO NOT SCALE DRAWINGS. CONTACT ARCHITECT IMMEDIATELY WITH ANY DISCREPANCIES.
4. VERIFY ALL EQUIPMENT ROUGH IN DIMENSIONS WITH SUBCONTRACTS PRIOR TO RELEASING EQUIPMENT FOR ORDERING.

$$\frac{1}{A1}$$

FLOOR PLAN

SCALE: 1/16" = 1'-0"

INTERIOR WALL IW-1:

5/8" GYPSUM WALL BOARD
3-5/8" METAL WALL STUDS @ 16" O.C.
5/8" GYPSUM WALL BOARD

DOOR AND FRAME SCHEDULE														
ID	SIZE			DOOR			FRAME			HRDWR GROUP	RATING	MIN REQ R-VALUE	QTY	NOTES
	W	HT	THK	TYPE	MATL	FINISH	TYPE	MATL	FINISH					
D1	3'-0"	7'-0"	1 3/4"	HALF	HM	PTD	SINGLE	HM	PTD	1	NR	7.14	4	
D2	3'-0"	7'-0"	1 3/4"	HALF	HM	PTD	SINGLE	HM	PTD	2	NR	7.14	10	
D3	3'-0"	7'-0"	1 3/4"	FLUSH	HM	PTD	SINGLE	HM	PTD	2	NR	7.14	1	
D4	12'-0"	14'-0"	2"	OH1	INSLM	PRFN	OHF	STL	GALV	3	NR	5	8	
D5	9'-0"	9'-0"	2"	OH1	INSLM	PRFN	OHF	STL	GALV	3	NR	5	4	
D6	14'-0"	14'-0"	2"	OH1	INSLM	PRFN	OHF	STL	GALV	3	NR	5	2	

ABBREVIATIONS:


NOTE	DESCRIPTION
HALF:	HALF LITE GLAZING
FLUSH:	FULL FLUSH PANEL
OH1:	OVERHEAD DOOR WITH (3) 26" X 13" LITES
HM:	HOLLOW METAL
INSLM:	INSULATED METAL
PTD:	PAINTED FINISH
PRFN:	FACTORY PRE-FINISH
SINGLE:	SINGLE SWING FRAME
OHF:	OVERHEAD TRACK AND FRAME SYSTEM
STL:	PRIMED STEEL
GALV:	GALVANIZED STEEL
NR:	NOT RATED
60	60 MIN RATED

DOOR AND FRAME NOTES

1. GLAZING IN DOORS SHALL BE TEMPERED WHERE REQUIRED BY THE 2015 IBC.
2. ALL THRESHOLDS AT INTERIOR AND EXTERIOR DOORS SHALL NOT EXCEED 1/2" IN HEIGHT.
3. DO NOT INSTALL HARDWARE THAT REQUIRES TIGHT GRASPING, PINCHING OR TWISTING OR THE WRIST FOR OPERATION.
4. INSTALL ALL DOOR LOCK-SETS, HANDLES, PUSH/PULLS, AND PANIC BARS AT 36" A.F.F.
5. DOOR LEAFS SHALL NOT REQUIRE MORE THAN A SINGLE OPERATION TO UNLATCH.

HARDWARE GROUPS

GROUP 1:	LOCKSET; ENTRY	GROUP 3:	
1	CLOSER	1	OH TRACK SYSTEM
1.5	PR HINGES	1	CLOSER
1	WEATHER-SEAL	1	WEATHER-SEAL
1	STOP		
1	THRESHOLD		
GROUP 2:	LOCKSET; STOREROOM		
1.5	PR HINGES		
1	WEATHER-SEAL		
1	STOP		
1	THRESHOLD		
2	KICKPLATES		

WINDOW SCHEDULE	
ID	W1
VIEW	
NOM SIZE	4' x 3'
TYPE	SLIDERS
QTY	6
MIN U-VALUE	.23

WINDOW NOTES

1. PROVIDE INTERIOR SCREEN AT ALL OPERABLE UNITS.