

ELECTRICAL SYMBOL LEGEND

USE THOSE THAT APPLY

- S 120/277 V., 20 AMP., SINGLE POLE LIGHT SWITCH.
- S 3 120/277 V., 20 AMP., THREE WAY SWITCH.
- S D 120/277 V., 20 AMP., SINGLE POLE LIGHT SWITCH W/DIMMER
- ELECTRICAL PANEL
- DISCONNECT SWITCH. "3" INDICATES NUMBER OF POLES. "60" = FRAME SIZE AND "F" DENOTES FUSE SIZE AS RECOMMENDED BY EQUIPMENT MANUFACTURER.
- ⊙ EXHAUST FAN
- ⊕ 20 A., 120., V., DUPLEX RECEPTACLE, GROUNDING TYPE, U.O.N. MOUNTED 18" A.F.F. OR AS DIRECTED BY ARCHITECT.
- ⊕ 20 A., 120., V., SINGLE RECEPTACLE, GROUNDING TYPE, U.O.N. MOUNTED 18" A.F.F. OR AS DIRECTED BY ARCHITECT.
- ⊕ SPECIAL PURPOSE RECEPTACLE TO MATCH EQUIPMENT PLUG
- ⊕ 20 A., 120., V., QUAD RECEPTACLE, U.O.N. MOUNTED 18" A.F.F. OR AS DIRECTED BY ARCHITECT.
- ⊕ FLOOR (FLUSH) MOUNT 20 A., 120., V., QUAD RECEPTACLE AND PHONE/DATA OUTLET.
- ⊕ PHONE/DATA OUTLET ⌀ 1/8" A.F.F. OR AS DIRECTED BY ARCHITECT. (4" BOX W/3/4" EMPTY CONDUIT TO CEILING SPACE). PROVIDE PULL STRING
- ⊕ 4"x4" POWER J-BOX FOR FINAL LOCATIONS, CONSULT WITH MODULAR FURNITURE MANUFACTURER.
- ⊕ 4"x4" DATA J-BOX FOR FINAL LOCATIONS, CONSULT WITH MODULAR FURNITURE MANUFACTURER.
- WP WEATHERPROOF
- E EXISTING TO REMAIN
- GFI GROUND FAULT INTERRUPTER


1.- ALL AHU's HAVE BEEN RELOCATED.
 2.- FOR ACCESS CONTROL EQUIPMENT LOCATION, SECURITY CAMERAS, OTHER RELATED DEVICES, WIRING AND CONDUIT ROUTING REFER TO SECURITY CONSULTANT SHOP DRAWINGS.

Power Plan
 2nd Floor
 Scale: 3/16" = 1'-0" N

REVISIONS

1	(OWNER CHANGES)
---	-----------------

Larry Johnston - Architect
 Architecture - Planning
 18555 NE 5th Court, Miami, Florida 33162
 Florida Registration # AR0014302 Telephone 305 944 6966



Novelty Design Group
 2451 Brickell Avenue, Suite 6T
 Miami, Florida V.305.301.1954. F.305.285.4390

Office Renovation for: DATAPRO
 770 Ponce de Leon Boulevard
 Coral Gables, Florida 33134

SHEET TITLE: 2nd FLOOR POWER PLAN

PROJECT NO:	COM-05-04
DRAWN BY:	A.G.
DATE:	10/13/04
SCALE:	3/16" = 1'-0"
SHEET NO:	E-1

JORGE LLAMA P.E.
 Professional Engineer
 State of Florida - License No. 60156
 Date:

Tronix, Inc.
 11309 SW 24TH TERR. Project Manager:
 MIAMI, FL 33165 ANTONIO GUTIERREZ
 PH: (305)225-7414 email: tronixinc@bellsouth.net