



NOTES

1. ALL PARTITIONS AND PARTITION LAYOUT SHALL BE APPROVED BY ARCHITECT PRIOR TO COMMENCING CONSTRUCTION.
2. ALL DIMENSIONS ARE FINISH FACE TO FINISH FACE UNLESS OTHERWISE NOTED.
3. ALL METAL STUDS TO BE MINIMUM GAUGE OF 1/8 GYPSUM #5720 STUDS OR EQUAL, UNLESS OTHERWISE NOTED.
4. CONTRACTOR TO REFER TO REFLECTED CEILING PLAN AND DETAILS FOR ALL FLASHINGS/SCOFFITS AND TRIMMED OPENING.
5. PROVIDE ADEQUATE BLOCKING SUPPORTS WITHIN DRYWALL PARTITIONS AND CEILING TO SUPPORT ALL WOODWORK ITEMS, GLASS FASCIAS & SOFFITS AND OTHER INSTALLATIONS AS REQUIRED.
6. CONTRACTOR TO INCLUDE COSTS FOR FLASH PATCHING, AND/OR CUTTING OF DOORS OR FRAMES TO ALLOW TRUE LEVEL AND STRAIGHT INSTALLATION OF ALL DOORS, FRAMES AND OTHER FIXED ITEMS.
7. ALL EXISTING WALLS TO REMAIN OR ALL WALLS AFFECTED BY DEVOLITION OR NEW CONSTRUCTION TO BE PATCHED - PROVIDE CORNER BEADS IF REQUIRED, TAPE AND SPACKLE PREPARE TO ACCEPT NEW FINISH.
8. CONTRACTOR SHALL SUBMIT SHOP DRAWINGS AND/OR SAMPLES FOR ALL FURNITURE WORK FOR ARCHITECT'S REVIEW PRIOR TO FABRICATION OR COMPLETION OF WORK.
9. ALL CONSTRUCTION DOCUMENTS ARE COMPLEMENTARY (ARCH, ENGR, ETC) AND WHAT IS CALLED FOR BY ANY WILL BE BINDING AS IF CALLED FOR BY ALL. ANY WORK SHOWN OR REFERRED TO ON ANY CONSTRUCTION DOCUMENT SHALL BE PROVIDED AS THOUGH ON ALL RELATED DOCUMENTS.
10. DRYWALL INSTALLER/CONTRACTOR TO COORDINATE WORK WITH HVAC CONTRACTOR FOR ALL WALL OPENING AT WALL AS REQUIRED.
11. ALL EXISTING CORNER WALL INCLUDING ALL COLLUMS TO BE LAMINATED WITH ONE LAYER OF 5/8" GYPSUM BOARD FROM FLOOR SLAB TO SLAB ABOVE OR 6" ABOVE CLR. VERIFY EXTENT OF WORK AND INCLUDE ALL COST AT TIME OF BID. CORRIDOR PARTITIONS SHALL HAVE GYPSUM BOARD TO UNDERSIDE OF SLAB.
12. EXISTING FLOOR SLAB TO BE PATCHED REPAIRED AND LEVELLED TO RECEIVE NEW FINISH. SEE FINISH PLAN. VERIFY EXTENT IN FIELD AND INCLUDE ALL COST AT BID.
13. PROVIDE METAL ACCESS PANEL AS REQUIRED FOR ALL WALLS OR COLUMN ENCLOSURES AS REQUIRED. VERIFY AND COORDINATE WITH ENGINEERS AS REQUIRED.
14. PROVIDE CORNER FABRIC TUCK CORNER PATCHING-SOFFITS #50-8040-40. TO TUCK IN WALLCOVERING. SEE FINISH PLAN.
15. CHOP EXISTING WALL AS REQUIRED TO ACCOMMODATE THE INSTALLATION OF ELECTRICAL BACKBOX AT LAMINATED PERIMETER WALL. SEE ELECTRICAL PLAN FOR AND VERIFY IN FIELD FOR ALL LOCATIONS. INCLUDE COST IN BID.

LEGEND

SCALE: NTS.

- EXISTING CONSTRUCTION TO BE REMAIN
- CONSTRUCTION TO BE REMOVED
- FILL HEIGHT DRYWALL PARTITION TO MATCH EXISTING REMOVE WALLS AS AFFECTED BY DEVOLITION SPECIFICATIONS AND CONSTRUCTION TO MATCH ADJACENT EXISTING WALL VERIFY IN FIELD.
- FILL HEIGHT 1-HOUR FIRE RATED DEMISING PARTITION 3-5/8" METAL STUDS @ 16" O.C. WITH (1) LAYER OF 5/8" THICK FIRECODE TYPE 'X' GYP. BD. ON EACH SIDE FROM FL. SLAB TO SLAB ABOVE. PROVIDE SEALANT AT ALL JOINTS AT SLABS AS REQUIRED. PROVIDE SOUND ATTENUATION BLANKET WITHIN PARTITION.
- FILL HEIGHT 2-HOUR FIRE RATED DEMISING PARTITION 3-5/8" METAL STUDS @ 16" O.C. WITH (2) LAYERS OF 5/8" THICK FIRECODE TYPE 'X' GYP. BD. ON EACH SIDE FROM FL. SLAB TO SLAB ABOVE. PROVIDE SEALANT AT ALL JOINTS AT SLABS AS REQUIRED. PROVIDE SOUND ATTENUATION BLANKET WITHIN PARTITION.
- FILL HEIGHT 2-HOUR FIRE RATED MASONRY PARTITION 6" CONCRETE MASONRY UNIT WITH 5/8" GYP. BD. / FIBERGLASS CHANNEL. SEE DETAIL.
- FILL HEIGHT 2-HOUR FIRE RATED SHUTTLEWALL PARTITION 1 1/2" CMU AT 16" O.C. WITH TWO LAYERS 5/8" GYP. BD. / THERMAFIBER SOUND ATTENUATION FIRE BLANKETS SEE DETAIL.
- FILL HEIGHT DRYWALL - SOUNDROOFED PARTITION 3-5/8" METAL STUDS @ 16" O.C. FROM SLAB TO SLAB WITH 5/8" THICK GYP. BD. (TYP. N) ON EACH SIDE FROM FLOOR SLAB TO UNDERSIDE OF EXISTING DECK. W/ AN SOUND ATTENUATION BLANKET IN BETWEEN STUDS. TYP. GENERAL - FILL HEIGHT DRYWALL PARTITION 3-5/8" METAL STUDS @ 16" O.C. FROM FLOOR SLAB TO SLAB WITH 5/8" THICK GYP. BD. ON EACH SIDE FROM FLOOR SLAB TO 6" ABOVE SPRINGED CEILING.
- FILL HEIGHT PLUMBING CHASE PARTITION 5/8" THICK GYP. BD. AT PAINTER SIDE AND RESISTANT GYPSUM BOARD AT OTHER SIDE AND STANDARD 5/8" THICK GYPSUM BOARD AT OTHER SIDE FROM FLOOR SLAB TO SLAB ABOVE. PROVIDE CONTINUOUS SOUND ATTENUATION BLANKET WITHIN PARTITION ALL FLOOR PENETRATIONS SHALL BE FIRE STOP SEALED.
- FILL HEIGHT DRYWALL FERRISS PARTITION 1-5/8" METAL STUDS OR 45 REED @ 16" O.C. WITH ONE LAYER 5/8" THICK GYPSUM BOARD AT EXPOSED SIDE FROM FLOOR SLAB TO 6" ABOVE SPRINGED CEILING.
- METAL / GLASS PARTITION
- ACQ ARCHITECTURAL WALL - 1/2" SERIES' COLOR SONGP N CONDUCTION W/ ARCHITECTIVE TRAVELER'S TRAVELER'S GLASS 005-1145
- 1-HR RATED METAL / GLASS PARTITION
- ACQ ARCHITECTURAL WALL - 1/2" SERIES' W/ WEATED STEEL FRAME IN CONJUNCTION W/ TYPICAL 60" X 80" VIN RATED GLASS (SEE FIELD)
- FILL HEIGHT PLUMBING CHASE PARTITION TYPICAL TO WALL TYPE #1 EXCEPT ONE LAYER OF 5/8" THICK WOODSRE RESISTANT GYP BD. AT PAINTER SIDE FROM FLOOR SLAB TO 6" ABOVE CEILING WITH 1/2" BATT INSULATION PROVIDE COMBINATION 1/2" BATT INSULATION ALL FLOOR PENETRATIONS SHALL BE FIRE STOP SEALED
- NEW DRYWALL LAMINATION 5/8" THICK GYPSUM BOARD PARTILED TO EXISTING PARTITION FROM FLOOR SLAB TO 6" ABOVE THE CEILING. LAMINATE ALL CORNER PARTITIONS AND COLLUMS TYPICAL UNLESS OTHERWISE NOTED
- ACCORDION PARTITION
- MFR. PANEL FOLD MODEL: SONICWALL 88 FINISH: PLASTIC LAMINATE BY MILSMAART COLOR: BISOLE
- NEW BLOCKING TO FILL EXISTING AND/OR BLOCKED TO ALIGN WITH EXISTING WALL TO MATCH EXISTING TYPE
- NEW WOODWORK (SEE ELEVATION / SECTION DWGS)
- ROOM OR AREA NUMBER
- SECTION OR ELEVATION
- DWG. NO.
- DWG. NO.
- INTERIOR ELEVATION
- CORNER GUARD
- MFR. FIN. STYLE FLUSH MOUNT CORNER GUARD COLOR: WOODRIFT
- DOOR NO.
- DOOR NO. (SEE DOOR & HARDWARE SCHEDULE A-8.0)
- ALIGN
- FIRE EXTINGUISHER CABINET
- MFR. L. INDUSTRIES INCORPORATED
- STYLE: ENBA957 555A/15
- CLOSET: HANGER ROD TO BE 1/2" GALV. #3304 @ 1-1/2" DIA. ANDER, CHROME PLATED MOUNTED AT 5'-6" AFF AND 1'-0" FROM REAR WALL. HAT SHELF TO BE 1-1/2" DEEP X 3/4" THICK BIRCH PLYWOOD WITH HARDWOOD EDGE AND 2 COATS OF CLEAR LACQUER FINISH. MOUNTED AT 5'-0" AFF WITH 3/4" X 3/4" CONTINUOUS ALUM. ANGLE AT SIDES AND BACK

ARCHITECTS PLANNERS CONSULTANTS



6321 New Utrecht Avenue  
Brooklyn, N.Y. 11219  
Tel. 718.259.1100  
Fax. 718.259.0111

THE ARCHITECT SHALL NOT HAVE CONTROL OR CHARGE OF AND SHALL NOT BE RESPONSIBLE FOR CONSTRUCTION MEANS, METHODS, DEVIATIONS, TECHNIQUES, SEQUENCES, OR PROCEDURES, OR FOR SAFETY PRECAUTIONS AND PROGRAMS IN CONNECTION WITH THE WORK, FOR THE ACTS OR OMISSIONS OF THE CONTRACTOR, SUBCONTRACTORS OR ANY OTHER PERSONS PERFORMING ANY OF THE WORK, OR FOR THE FAILURE OF ANY OF THEM TO CARRY OUT THE WORK IN ACCORDANCE WITH THE CONTRACT DOCUMENTS. ALWAYS USE DIMENSIONS AS SHOWN. DRAWINGS ARE NOT TO BE SCALED

Third Floor Plan  
Conversion of an Existing Manufacturing Building, to a health Facility for the City of New York.  
Located @ 716-722 Myrtle Avenue, Brooklyn, New York  
Client: Kings County Hospital Center

ISSUE:	DATE:	DESCRIPTION:
1	1-13-05	ISSUED FOR CONSTRUCTION
2	4-06-05	REVISED AS PER CLIENTS REQUEST
3	9-13-05	REVISED AS PER FIELD CONDITIONS
4	4-27-06	REVISION TO PLANS AS NOTED.

DRAWN BY: M.G.  
PROJECT NO.: 04-183  
DATE: 6-07-04  
DRAWING NO.: A-1.3  
OF