

LINCOLN COUNTY HEALTH DEPARTMENT

302 N. Academy Street
Lincolnton, N.C. 28092
(704) 732-9000

A COPY OF THIS PERMIT
MUST BE SUBMITTED TO
THE LINCOLN COUNTY
BUILDING INSPECTIONS
DEPARTMENT

PERMIT #: 425-0793

NAME: Maryvale Daycare ADDRESS: Junebug Rd / vale NC 28098 PHONE: 276-2626

OTHER: ADDRESS: PHONE:


DIRECTIONS TO PROPERTY: Reepsville Rd west, turn right on Junebug Rd

☐ HOUSE ☐ MOBILE HOME ☒ BUSINESS 32 children ☒ OTHER: Daycare
OF BEDROOMS: # OF EMPLOYEES: 30 children # OF SEATS: GPD: 450
☒ WELL ☐ SPRING ☐ PUBLIC WATER ☐ OTHER:

IMPROVEMENT PERMIT

☐ REPAIR ☐ LOT DENIED

TANK SIZE 1000 gal
NUMBER OF TRENCHES 54 (3'x100')
TOTAL SQUARE FEET 1200'
GRAVEL DEPTH 12"
DISTANCE TO WATER SUPPLY 100' +




COMMENTS Road
5' x 10' all property
lines & follow down of land

HEALTH DEPARTMENT REP. Scott Smer
DATE: 7-6-93

FINAL COMPLETION

☐ CERT. COMPL. ☐ RECONNECT ☐ OPER. PERMIT.

TANK MANUFACTURER & SIZE Stump 1000 gal
NUMBER OF TRENCHES 4 (3'x100')
TOTAL SQUARE FEET 1200'
DISTANCE TO WATER SUPPLY 100' +
INSTALLER Charles Henner



COMMENTS Road
checked tank & 3 lines
on 8-29-93 S.S.

HEALTH DEPARTMENT REP. Scott Smer
DATE: 8-30-93

IMPROVEMENT PERMIT: THIS IMPROVEMENT PERMIT IS VALID FOR (60) SIXTY MONTHS. THIS IMPROVEMENT PERMIT IS SUBJECT TO REVOCATION IF SITE PLANS OR THE INTENDED USE ARE CHANGED FROM THOSE SHOWN ON PERMIT. CHANGES FROM THE ABOVE PERMIT REQUIRE HEALTH DEPARTMENT APPROVAL.

FINAL COMPLETION: FINAL APPROVAL OF THIS SYSTEM SHALL INDICATE THAT THE SYSTEM HAS BEEN INSTALLED IN ACCORDANCE WITH STATE REGULATIONS, BUT IN NO WAY SHOULD BE TAKEN AS A GUARANTEE THAT THE SYSTEM WILL FUNCTION SATISFACTORY FOR ANY GIVEN TIME.

THIS SEWAGE DISPOSAL SYSTEM (IS) (IS NOT) INSTALLED ACCORDING TO THE N. C. SEWAGE RULES.

MARYVALE DAYCARE

NAME: