

Company Name and Mailing Address:

Amador Water Agency

Date Due:

4/19/2024

Notice:

☒ 1st.

☐ 2nd.

Service Address:

360 Sutter Hill Rd.

Owner :

Dennis Griffin

Type RP	Manufacturer Febco	Model No. 825Y	Serial No. 205379	Size: 2.0"	Account No./Meter No. 1544429694
Location of Device: Right of Driveway					
Type & Tests	Reduced Pressure Devices			Pressure Vacume Breaker	
	Double Check Devices			Air Inlet	Check Valve
	No. 1 Check DC _____psid.	No. 2 Check DC _____psid.			
Initial Test	Closed Tight <input checked="" type="checkbox"/> RP_7.0_psid. Leaked <input type="checkbox"/>	Closed Tight <input checked="" type="checkbox"/> Leaked <input type="checkbox"/>	Opened at _____.2.4_psid.	Opened at _____.psid. Did not Open <input type="checkbox"/>	Closed Tight at _____.psid. Leaked <input type="checkbox"/>
Initial Results: <input checked="" type="checkbox"/> Passed <input type="checkbox"/> Failed <input type="checkbox"/> Needs Repair <input type="checkbox"/> Needs Replacement					
Repairs & Materials Used:					
Test After Repairs	DC Closed Tight <input type="checkbox"/> RP_____psid.	Closed Tight <input type="checkbox"/>	Opened at _____.psid.	Opened at _____.psid.	Closed Tight at _____.psid.
Final Results: <input checked="" type="checkbox"/> Passed <input type="checkbox"/> Failed					
Comments:					

The Above Report is Certified to be True

Date: 4/19/2024	Testing Firm: Garett's Cross-Connection Control	Tester No: O8417	Exp. Date: 4/20/2027	Tester Signature: Garett Walker
--------------------	--	---------------------	-------------------------	------------------------------------



Garett's Cross-Connection Control

Company Name and Mailing Address:

Amador Water Agency

Date Due:

4/19/2024

Notice:

☒ 1st.

☐ 2nd.

Service Address:

360 Sutter Hill Rd.

Owner :

Dennis Griffin

Type DC	Manufacturer Wilkins	Model No. 950XL	Serial No. 4177498	Size: 0.75"	Account No./Meter No. 1544429694
Location of Device:		Right of Driveway Dector Check on the Fire Service			
		Dector Meter # 48106645			
Type & Tests	Reduced Pressure Devices			Pressure Vacume Breaker	
	Double Check Devices			Air Inlet	Check Valve
	No. 1 Check DC_2.4_psid.	No. 2 Check DC_3.0_psid.			
Initial Test	Closed Tight <input checked="" type="checkbox"/> RP____psid.	Closed Tight <input checked="" type="checkbox"/> Leaked <input type="checkbox"/>	Opened at ____psid.	Opened at ____psid.	Closed Tight at ____psid.
	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>		Did not Open <input type="checkbox"/>	Leaked <input type="checkbox"/>
Initial Results:					
<input checked="" type="checkbox"/> Passed <input type="checkbox"/> Failed <input type="checkbox"/> Needs Repair <input type="checkbox"/> Needs Replacement					
Repairs & Materials Used:					
Test After Repairs	DC Closed Tight <input type="checkbox"/> RP____psid.	Closed Tight <input type="checkbox"/>	Opened at ____psid.	Opened at ____psid.	Closed Tight at ____psid.
Final Results:					
<input checked="" type="checkbox"/> Passed <input type="checkbox"/> Failed					
Comments:					

The Above Report is Certified to be True

Date: 4/19/2024	Testing Firm: Garett's Cross-Connection Control	Tester No: 08417	Exp. Date: 4/20/2027	Tester Signature: Garett Walker
--------------------	--	---------------------	-------------------------	------------------------------------



Garett's Cross-Connection Control

Company Name and Mailing Address:

Amador Water Agency

Date Due:

4/19/2024

Notice:

☒ 1st.

☐ 2nd.

Service Address:

360 Sutter Hill Rd.

Owner :

Dennis Griffin

Type DC	Manufacturer Wilkins	Model No. 950XL	Serial No. 4733B	Size: 4.0"	Account No./Meter No. 1544429694
Location of Device:		Fire Service Right of Driveway			
		Dector Meter # 48106645			
Type & Tests	Reduced Pressure Devices			Pressure Vacume Breaker	
	Double Check Devices			Air Inlet	Check Valve
	No. 1 Check DC_3.2_psid.	No. 2 Check DC_2.8_psid.			
Initial Test	Closed Tight <input checked="" type="checkbox"/> RP____psid.	Closed Tight <input checked="" type="checkbox"/> Leaked <input type="checkbox"/>	Opened at ____psid.	Opened at ____psid.	Closed Tight at ____psid.
	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>		Did not Open <input type="checkbox"/>	Leaked <input type="checkbox"/>
Initial Results:					
<input checked="" type="checkbox"/> Passed <input type="checkbox"/> Failed <input type="checkbox"/> Needs Repair <input type="checkbox"/> Needs Replacement					
Repairs & Materials Used:					
Test After Repairs	DC Closed Tight <input type="checkbox"/> RP____psid.	Closed Tight <input type="checkbox"/>	Opened at ____psid.	Opened at ____psid.	Closed Tight at ____psid.
Final Results:					
<input checked="" type="checkbox"/> Passed <input type="checkbox"/> Failed					
Comments:					

The Above Report is Certified to be True

Date: 4/19/2024	Testing Firm: Garett's Cross-Connection Control	Tester No: O8417	Exp. Date: 4/20/2027	Tester Signature: Garett Walker
--------------------	--	---------------------	-------------------------	------------------------------------



Garett's Cross-Connection Control