



**ALAMANCE COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH SECTION**



Improvement Permit- New

A Construction Authorization must be purchased to obtain a building permit (This is not a Construction Authorization)

| | | | |
|-----------------------------------|---------------------------|-------------------------------------|------------------------------------|
| Tax Map Number 5-23-128 | GPIN 8877521259 | Application Date 3/9/2021 | Permit Number 6190IMPR21 |
|-----------------------------------|---------------------------|-------------------------------------|------------------------------------|

Site Address 0 N 62 HWY. BURLINGTON, NC 27217
FRANK E AND JULIAN BOYD BELL LOT # 1

Directions HWY 62 NORTH TO FIVE POINTS STRAIGHT ACROSS FROM LIGHT

| | | | |
|------------------|---|--------------|--|
| Applicant | VINCENT DAVID TODD 317 JORDAN CREEK DR BURLINGTON, NC 27217 (336) 221-0776 | Owner | BELL JULIAN BOYD 1411 BOONE RD. BURLINGTON, NC 27217 |
| Phone | | Phone | |
| Fax | | Fax | |
| Other | (336) 269-2154 | Other | |
| Email | toddsaffordable@aol.com | Email | |

| | | | |
|---|------------------------------------|-----------------------------|--------------------|
| Type of Structure | BUSINESS | Business Type | Businesses - other |
| Pump Required | Yes | Business Sub-Type | n/a |
| Grease Trap Required | No | Number of employees | 15 |
| Design Daily Flow | 375 GPD | | |
| Permit Valid For | Expires 5/14/2026 | Type of Water Supply | Well |
| Wastewater System Type | Pump Type IIIb | | |
| System Description | Pump to Conventional Septic System | | |
| System Distribution | SERIAL | | |
| Repair System Type | Pump Type IIIb | | |
| Repair Description | Pump to PPBPS, Horizontal | | |
| Repair System Distribution | PRESSURE MANIFOLD | | |
| LTAR - Initial | 0.250 | LTAR - Repair | 0.250 |
| Usable soil depth to Limiting Condition for Initial area | 41 inches | | |
| Usable soil depth to Limiting Condition for Repair area | 26 inches | | |
| Minimum Trench Depth | 18 inches | | |
| Maximum Trench Depth | 29 inches | | |

Permit Conditions:

All pump designs and installations shall be in accordance with the Laws and Rules for Sewage Treatment, and Disposal Systems 15A NCAC 18E subject to approval by Alamance County Health Department.

See Attached Site Sketch

The issuance of this permit in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. *This permit is subject to revocation if the site plan, plat, or the intended use changes.* The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of 15A NCAC 18E and to the conditions of this permit.

Authorized State Agent Jason Shelton

Date 5/14/2021