


DESIGN LIVE LOAD	
FLOOR	60 PSF
ROOF	35 PSF
(WITH APPROPRIATE INCREASE FOR DRIFTING SNOW AS PER M.A. STATE BUILDING CODE)	
WIND	11 PSF
SEISMIC DESIGN	
GROUP	I
CATEGORY	C
S ₁	R = 6
C _d	1.4

1. FOUNDATIONS ARE DESIGNED FOR NINTH BEARING ON UNDISTURBED SOIL OF TWO (2) TONS PER SQUARE FOOT.
2. ALL EXTERIOR FOOTINGS SHALL BE CARRIED A MIN. OF 4'-0" BELOW FINISH GRADE.
3. NO FOOTING SHALL BE PLACED IN WATER OR ON FROZEN GROUND.
4. BACKFILL SHALL NOT BE PLACED AGAINST FOUNDATION WALLS UNLESS THEY ARE PROPERLY BRACED.
5. COORDINATE WITH ELECTRICAL, PLUMBING, AND OTHER CONTRACTORS, LOCATION AND ELEVATIONS OF ALL LINES, SLEEVES AND RISERS.

1. ALL CONCRETE WORK SHALL CONFORM TO THE LATEST REQUIREMENTS OF "BUILDING CODE REQUIREMENTS FOR REINFORCED CONCRETE," ACI 318 AND "SPECIFICATIONS FOR STRUCTURAL CONCRETE FOR BUILDINGS," ACI 301, AS SUPPLEMENTED BY THE PROJECT SPECIFICATIONS.
2. ALL CONCRETE WORK SHALL HAVE A MINIMUM COMPRESSIVE STRENGTH AT THE END OF 28 DAYS AS FOLLOWS:

FOOTINGS AND FOUNDATION WALLS	3000 PSI
INTERIOR AND EXTERIOR SLABS	4000 PSI
3. ALL REINFORCING STEEL SHALL BE NEW INTERMEDIATE GRADE BILLET STEEL AND SHALL CONFORM TO ASTM GRADE A-66 GRADE 60. ALL BARS SHALL BE 2" DIAMETERS MINIMUM.

1. INSTALL R30 FIBERGLASS BATT INSULATION BETWEEN FLOOR JOISTS (NEW & EXISTING) ALL AREAS. INSTALL CHICKEN WIRE TO BOTTOM OF JOISTS TO HOLD INSULATION IN PLACE.



SECTION 1
SCALE: 1/2" = 1'-0"

PROPOSED ADDITION:
MURPHY INSURANCE AGENCY

Drawing Numbers:

SCALE:	AS NOTED
DATE:	1 AUGUST 2003
DRAWN:	JR
CHECKED:	NRO
PROJ. NO.:	23013

Dixon Salo Architects, Inc.
50 Franklin Street
Worcester, MA 01608
Tel. (508) 755-0533
Fax. (508) 799-3862

Revisions: