

**CERTIFICATION OF COMPLIANCE WITH PARKING LOT ILLUMINATION
STANDARDS IN CHAPTER 8C OF THE CODE OF MIAMI-DADE COUNTY**

Date: 12/6/2024

RE: Case No.:

Not Provided

Property Address:

1362 SW 2 ST, BLDG.: 2, MIAMI, FL 33135

Building Description:

Two-Story Residential Building

1. I am a Florida registered professional engineer or architect with an active license.
2. On 11/8 2024, at 10:07 pm, I measured the level of illumination in the parking lot (s) serving the above referenced building.
3. Maximum 1.27 foot candle per SF, Minimum 1.08 foot candle per SF, Minimum to Maximum ratio 1:17, foot candle 1.17 average per SF.
4. The level of illumination provided in the parking lot (s) meets does not meet the minimum standards for the occupancy classification of the building as established in Section 8C-3 of the Code of Miami-Dade County.

Signature and Seal
of Architect or Engineer

James Hanskat, P.E.
(Print Name)

