



Burlington, WA Corporate Laboratory (a)
1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 • 360.757.1400

Bellingham, WA Microbiology (b)
805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

Portland, OR Microbiology/Chemistry (c)
9725 SW Commerce Cr Ste A2 - Wilsonville, OR 97070 - 503.682.7802

Corvallis, OR Microbiology/Chemistry (d)
1100 NE Circle Blvd, Ste 130 - Corvallis, OR 97330 - 541.753.4946

Bend, OR Microbiology (e)
20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425



Page 1 of 1

Drinking Water Report

Client Name: Mainline Pump & Irrigation
PO Box 869
Philomath, OR 97370

Reference Number: **24-12423**

Report Date: 5/10/24

Approved By: anp,mdp,rap

Authorized by:

Sarah P Miller
Lab Manager, Corvallis

Project: Logsden Country Store
Field ID: Sample at hose bibb
Sample Description: 7550 Logsden Rd, Logsden
Sample Date: 5/2/24 11:15

Lab Number: OR100009-23304
Date Received: 5/2/24
Sampled By: Sheila
Sampler Phone:

CAS Number	Analyte	Result	MCL	Pass [^]	Lab	QL	Units	Analyzed
Coli-To-t	TOTAL COLIFORM	Absent		Pass	d	P/A	per 100m	5/3/24
68583-22-2	E. Coli	Absent		Pass	d	Y/N	per 100m	5/3/24
14797-55-8	NITRATE-N	2.80	10	Pass	d	0.005	mg/L	5/3/24
7440-38-2	ARSENIC	ND	0.010	Pass	a	0.001	mg/L	5/8/24

Notation:

MCL = Maximum Contaminant Level, maximum permissible level of a contaminant in water established by EPA; Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper. Sodium has a recommended limit of 20 mg/L. A blank MCL value indicates a level is not currently established.
QL = Quantitation Limit is the lower calibration concentration.
ND = Not detected above the listed specified reporting limit (QL).

CAS Number = Chemical Abstract Service Number is a unique identifier of the chemical tested.

[^] = 'PASS', indicates that the parameter tested meets EPA, State, or local jurisdiction MCL. 'Exceeds' indicates EPA secondary limit (Aesthetic) was exceeded. 'Fail' indicates EPA Primary limit (Health) was exceeded.

An * in front of the parameter name indicates it is not NELAP accredited but it is accredited through OR DEQ or USEPA Region 10.

These test results meet all the requirements of NELAC, unless otherwise stated in writing, and relate only to these samples.
If you have any questions concerning this report contact Lawrence Henderson at the above phone number.

FORM: ShortList.rpt