



NOTES

1. ALL PARTITIONS AND PARTITION LAYOUT SHALL BE APPROVED BY ARCHITECT PRIOR TO COMMENCING CONSTRUCTION.
2. ALL DIMENSIONS ARE FINISH FACE TO FINISH FACE UNLESS OTHERWISE NOTED.
3. ALL METAL STUDS TO BE MINIMUM GAUGE OF 1/8 GYPSUM #5720 STUDS OR EQUAL, UNLESS OTHERWISE NOTED.
4. CONTRACTOR TO REFER TO REFLECTED CEILING PLAN AND DETAILS FOR ALL FLASHINGS/SCOTTS AND TRIMMED OPENING.
5. PROVIDE ADEQUATE BLOCKING SUPPORTS WITHIN DRYWALL PARTITIONS AND CEILING TO SUPPORT ALL WOODWORK ITEMS, GLASS FASCIAS & SCOTTS AND OTHER INSTALLATIONS AS REQUIRED.
6. CONTRACTOR TO INCLUDE COSTS FOR FLASH PATCHING - AND/OR CUTTING OF DOORS OR FRAMES TO ALLOW TRUE LEVEL AND STRAIGHT INSTALLATION OF ALL DOORS, FRAMES AND OTHER FIXED ITEMS.
7. ALL EXISTING WALLS TO REMAIN OR ALL WALLS AFFECTED BY DEVOLUTION OR NEW CONSTRUCTION TO BE PATCHED - PROVIDE CORNER BEADS IF REQUIRED, TAPE AND SPACKLE PREPARE TO ACCEPT NEW FINISH.
8. CONTRACTOR SHALL SUBMIT SHOP DRAWINGS AND/OR SAMPLES FOR ALL PERMENT WORK FOR ARCHITECT'S REVIEW PRIOR TO FABRICATION OR COMMENCEMENT OF WORK.
9. ALL CONSTRUCTION DOCUMENTS ARE COMPLEMENTARY (ARCH, ENGR, ETC) AND WHAT IS CALLED FOR BY ANY WILL BE BINDING AS IF CALLED FOR BY ALL. ANY WORK SHOWN OR REFERRED TO ON ANY CONSTRUCTION DOCUMENT SHALL BE PROVIDED AS THOUGH ON ALL RELATED DOCUMENTS.
10. DRYWALL INSTALLER/CONTRACTOR TO COORDINATE WORK WITH HVAC CONTRACTOR FOR ALL WALL OPENING AT WALL AS REQUIRED.
11. ALL EXISTING CORE WALL INCLUDING ALL COLUMNS TO BE LAMINATED WITH ONE LAYER OF 5/8" GYPSUM BOARD FROM FLOOR SLAB TO SLAB ABOVE OR 6" ABOVE CLR. VERIFY EXTENT OF WORK AND INCLUDE ALL COST AT TIME OF BID. CORRIDOR PARTITIONS SHALL HAVE GYPSUM BOARD TO UNDERSIDE OF SLAB.
12. EXISTING FLOOR SLAB TO BE PATCHED REPAIRED AND LEVELED TO RECEIVE NEW FINISH. SEE FINISH PLAN. VERIFY EXTENT IN FIELD AND INCLUDE ALL COST AT BID.
13. PROVIDE METAL ACCESS PANEL, AS REQUIRED FOR ALL WALLS OR COLUMN ENCLOSURES AS REQUIRED. VERIFY AND COORDINATE WITH ENGINEERS AS REQUIRED.
14. PROVIDE CORNER - FABRIC TUCK CORNER PUTTICKON - SCOTTS #50-R8060-40. TO TUCK IN WALLCOVERING. SEE FINISH PLAN.
15. CHOP EXISTING WALL AS REQUIRED TO ACCOMMODATE THE INSTALLATION OF ELECTRICAL BACKBOX. AT LAMINATED PERIMETER WALL, SEE ELECTRICAL PLAN FOR AND VERIFY IN FIELD FOR ALL LOCATIONS. INCLUDE COST IN BID.

LEGEND

SCALE: N.T.S.

- EXISTING CONSTRUCTION TO BE REMOVED
- CONSTRUCTION TO MATCH EXISTING
- FILL HEIGHT DRYWALL PARTITION TO MATCH EXISTING
- EXISTING WALLS AS AFFECTED BY DEVOLUTION SPECIFICATIONS AND CONSTRUCTION TO MATCH ADJACENT EXISTING WALL VERIFY IN FIELD.
- FILL HEIGHT 1-HOUR FIRE RATED DEMISING PARTITION
- 3-5/8" METAL STUDS @ 16" O.C. WITH (1) LAYER OF 5/8" THICK FIRECODE TYPE 'X' GYP. BD. ON EACH SIDE FROM FL. SLAB TO SLAB ABOVE. PROVIDE SEALANT AT ALL JOINTS AT SLABS AS REQUIRED. PROVIDE SOUND ATTENUATION BLANKET WITHIN PARTITION.
- FILL HEIGHT 2-HOUR FIRE RATED DEMISING PARTITION
- 3-5/8" METAL STUDS @ 16" O.C. WITH (2) LAYERS OF 5/8" THICK FIRECODE TYPE 'X' GYP. BD. ON EACH SIDE FROM FL. SLAB TO SLAB ABOVE. PROVIDE SEALANT AT ALL JOINTS AT SLABS AS REQUIRED. PROVIDE SOUND ATTENUATION BLANKET WITHIN PARTITION.
- FILL HEIGHT 2-HOUR FIRE RATED MASONRY PARTITION
- 6" CONCRETE MASONRY JOINT WITH 5/8" 6" GYP. BD. / FIBERING CHANNEL. SEE DETAIL.
- FILL HEIGHT 2-HOUR FIRE RATED SHUTTLEWALL PARTITION
- 1 1/2" CH STUD AT 16" O.C. WITH TWO LAYERS 5/8" 6" GYP. BD. / THERMAFIBER SOUND ATTENUATION FIRE BLANKETS SEE DETAIL.
- FILL HEIGHT DRYWALL - SOUNDROOFED PARTITION
- 3-5/8" METAL STUDS @ 16" O.C. FROM SLAB TO SLAB WITH 5/8" THICK GYP. BD. (TYP. N) ON EACH SIDE FROM FLOOR SLAB TO UNDERSIDE OF EXISTING DECK, W/ AN SOUND ATTENUATION BLANKET IN BETWEEN STUDS. TYP.
- GENERAL - FILL HEIGHT DRYWALL PARTITION
- 5/8" METAL STUDS @ 16" O.C. FROM FLOOR SLAB TO FLOOR SLAB TO 6" ABOVE SPRINGED CEILING.
- FILL HEIGHT PLUMBING CHASE PARTITION
- 5/8" METAL STUDS @ 16" O.C. FROM FLOOR SLAB TO FLOOR SLAB TO 6" ABOVE SPRINGED CEILING.
- RESISTANT GYPSUM BOARD AT PAINTY SIDE AND STANDARD 5/8" THICK GYPSUM BOARD AT OTHER SIDE FROM FLOOR SLAB TO SLAB ABOVE. PROVIDE CONTINUOUS SOUND ATTENUATION BLANKET WITHIN PARTITION ALL FLOOR PENETRATIONS SHALL BE FIRE STOP SEALED.
- FILL HEIGHT DRYWALL FIBERING PARTITION
- 1 1/2" METAL STUDS OR 45 REED @ 16" O.C. WITH ONE LAYER 5/8" THICK GYPSUM BOARD AT EXPOSED SIDE FROM FLOOR SLAB TO 6" ABOVE SPRINGED CEILING.
- VETAL / GLASS PARTITION
- AOE ARCHITECTURAL WALL - "80 SERIES" COLOR 5056P IN CONJUNCTION W/ ARCHITECT'S FINISHES TRAVELERBLANKET 6155 0052-1145
- 1.8X RATED METAL / GLASS PARTITION
- AOE ARCHITECTURAL WALL - "80 SERIES" W/ MENDED SITE. FRAME IN CONJUNCTION W/ "PROBEEL 60" 80 VNL RATED GLASS. VEA-414294X1.
- FILL HEIGHT PLUMBING EXPOSED-OUT PARTITION
- TYPICAL TO WALL TYPE #1 EXCEPT ONE LAYER OF 5/8" THICK MOISTURE RESISTANT GYP. BD. AT PAINTY SIDE FROM FLOOR SLAB TO 6" ABOVE CEILING. VEA IN WITH BATT INSULATION. PROVIDE DOWNS WITH 1/2" TOL TYPED BATT INSULATION.
- VEN DRYWALL LAMINATION
- 5/8" THICK GYPSUM BOARD APPLIED TO EXISTING PARTITION FROM FLOOR SLAB TO 6" ABOVE THE CEILING. LAMINATE ALL CORNER PARTITIONS AND COLLINGS TYPICAL UNLESS OTHERWISE NOTED.
- ACCORDION PARTITION
- MFR. PANEL FOLD MODEL: SONICWALL 88 FINISH: PLASTIC LAMINATE BY MILESMAART COLOR: BISOLE
- NEW BLOCKING TO FILL EXISTING HANDSOME BACKBOX TO ALIGN WITH EXTERIOR WALL TO MATCH EXISTING TYPE
- NEW WOODWORK (SEE ELEVATION / SECTION DWGS)
- ROOM OR AREA NUMBER
- SECTION OR ELEVATION
- DWG. NO.
- DIMS. NO.
- INTERIOR ELEVATION
- CORNER GUARD
- MFR. IPC STYLE: FLUSH W/NT CORNER GUARD COLOR: WOODGRAFT
- DOOR NO.
- DOOR & HARDWARE SCHEDULE A-8-0
- ALIGN
- FIRE EXTINGUISHER CABINET
- MFR. L. INDUSTRIES INCORPORATED STYLE: ENHANCED 5654/5
- CLOSET: HANGER ROD TO BE "SARGO" #33584 @ 1-15/16" DIA/ENTER, CHROME PLATED MOUNTED AT 5'-6" AFF AND 1'-0" FROM REAR WALL. HAT SHELF TO BE 1-6" DEEP X 3/4" THICK BIRCH PLYWOOD WITH HARDWOOD EDGE AND 2 COATS OF CLEAR LACQUER FINISH, MOUNTED AT 5'-10" AFF WITH 3/4" X 3/4" CONTINUOUS ALUM. ANGLE AT SIDES AND BACK

Second Floor Plan

Conversion of an Existing Manufacturing Building, to a health Facility for the City of New York. Located @ 716-722 Myrtle Avenue, Brooklyn, New York

Client: Kings County Hospital Center

ISSUE:	DATE:	DESCRIPTION:
1-13-05	ISSUED FOR CONSTRUCTION	
4-06-05	REVISED AS PER CLIENT'S REQUEST	
9-13-05	REVISED AS PER FIELD CONDITIONS	
4-27-06	REVISION TO PLANS AS NOTED	

DESIGN BY: M.G.
PROJECT NO.: 04-183
DATE: 6-07-04
DRAWING NO.: A-1.2

ARCHITECTS
PLANNERS
CONSULTANTS

6321 New Utrecht Avenue
Brooklyn, N.Y. 11219
Tel. 718.259.1100
Fax. 718.259.0111

BRICOLAGE
d · e · s · i · g · n · s

THE ARCHITECT SHALL NOT HAVE CONTROL OR CHARGE OF AND SHALL NOT BE RESPONSIBLE FOR CONSTRUCTION MEANS, METHODS, DEVIATIONS, TECHNIQUES, SEQUENCES, OR PROCEDURES, OR FOR SAFETY PRECAUTIONS AND PROGRAMS IN CONNECTION WITH THE WORK, FOR THE ACTS OR OMISSIONS OF THE CONTRACTOR, SUBCONTRACTORS OR ANY OTHER PERSONS PERFORMING ANY OF THE WORK, OR FOR THE FAILURE OF ANY OF THEM TO CARRY OUT THE WORK IN ACCORDANCE WITH THE CONTRACT DOCUMENTS. ALWAYS USE DIMENSIONS AS SHOWN. DRAWINGS ARE NOT TO BE SCALED