

Well Certificate of Completion

Buncombe County Environmental Health Services
30 Valley Street, Asheville, NC 28801
(828) 250-5016

Case No: WEL 2011-00332

PIN 9745 70 0146

Type Well: ☐ Single Family ☐ Shared ☐ Public ☐ Repair ☐ Abandonment

Owner Echoview Community Mill

Address 76 Jupiter Rd

Drilling Contractor/Company Clear Water Well Drilling

Construction

Total Depth 405

Casing Type: ☒ PVC ☐ Steel

Casing Depth 90'

Diameter: ☒ 6.25" ☐ 6.0"

Weight/Thickness: ☒ SDR 21 ☐ SDR 27 ☐ 0.185

Height 1'

Drive Shoe: ☐ yes ☒ no

GPM Flow 10.0

GPS Coordinates

Latitude N35° 45.577

Longitude W82° 32.964

Grout

Type: ☐ Neat Cement ☐ Sand Cement ☒ Concrete ☐ Gravel Cement ☐ Bentonite ☐ Specialty

Thickness 2"

Depth 20'

Date Drilled 12/22/2011

Grout Inspected By/Date: [Signature] PS 12/22/2011

**Contractor Certification For Grouting Not Witnessed By Dept _____ Date _____

Final Inspector/Date: [Signature] H.S. 3-7-2012

Water Samples Collected By/Date: _____

Comments: _____

Final Inspection

Hose Bibb ☒

Vent ☒

Pump Contractor Clear Water

Pump Installed Date 1-2-12

Pump Contractor ☒

ID Plate ☒

Well Contractor ☒

ID Plate ☒

Liner Installed ☐

Date _____

Well Abandonment ☐

Date _____

Sealant Material Silicon