



# TOWN OF ROCKLAND

Building Department

781-871-0596

## INSPECTION REQUEST

Date received: 2-28-24

No. & Street: 198-200 PLEASANT ST

Owner: \_\_\_\_\_

Telephone no.: \_\_\_\_\_

In person or written? \_\_\_\_\_

Authorized to request? Yes  No

### INSPECTION REQUESTED

Inspector: Jim

Building: \_\_\_\_\_

Wiring: CHECK SERVICE SIZE

Plumbing: \_\_\_\_\_

Gas: \_\_\_\_\_

Date requested for: THURS 2/29

Requested by: SEAN MAHONEY

617-799-4711

Call received by: \_\_\_\_\_ Time: \_\_\_\_\_

### DISPOSITIONS & COMMENTS

MAIN - 480 VOLT - 200A

4 WIRE - 3 PHASE w/

250 AMP 480 VOLT PANEL

+ FEEDS TRANSFORMER FOR

120/208 VOLT - 225 AMP

PANEL FEEDING VARIOUS

SUB PANELS

COURTESY INSPECTION

Signed: TIM PAUL

Date & Time: 2-29-24

White Copy - Inspector Retain  
Yellow Copy - File Location