



SEE 2ND FL. PLAN

D#1
3#12 3/4" C.

BUILDING

S#15
VIA TIME CLOCK #1
3#12 3/4" C.

S#17,19
VIA TIME CLOCK #2
4#10 U.F. CABLE

S#21,23,25
VIA TIME CLOCK #3 & 4
5#10 U.F. CABLE

PRI. 1-4" GRS. IN CONC. WITH
3#1 15 KV. POLY CENTRIC
ALL AS APPROVED BY CON ED.

PIPE SLEEVE. SEE DETAIL
(TYPICAL)

TELEPHONE SERVICE
FLOOR BOARD SEE FLOOR PLAN.

ELECTRIC & TEL. SERV. RM.

C.T., METER - MAIN DIST. PNL.
SUB-DIST. PNL SEE E-2 DWG.
FLOOR PLAN AND ONE LINE

THREE SET OF 4" PVC S
WITH 4 NO. 750 MCM THW
CONDUCTORS EACH. PROVIDE
SPARE DUCT WITH NYLON

1200 AMP 120/208 VO
UNDERGROUND SERV
SEE ONE LINE DIAGRAM

4-SETS 3 1/2" C. EACH
4-500 MCM THW CAP.

PAD MOUNT TRANSFORM
TRANSFORMER BY CON
1-300 KVA INSTALL PER
13827; E.O. 12181-C; E.O.
13756-C

PRI. CAP
1/0 ALU
7216-A
DETAIL

POLE
PER.
16351
E.O. 32
RISER
& E.O.

UNDE
4" TIE
PER.
SPECT.

TO CU
TEL. S
SERVI

PRIMARY OVERHEAD

OLD SAW MILL RIVER ROAD

POLE # W460

SITE PLAN

GOESTAL.
PVC.

HALL

ROOF