



Ector County Health Department

221 N. Texas
Odessa, TX 79761
(432) 498-4141

On-Site Sewage Facility Permit OSSF PERMIT #: 12829

Owner: Basin Industry Outfitters LLC
Location: 14010 Silverfox TR # 6 W, Odessa, TX
Lot 6
Installer: Arnulfo Lopez
Site Evaluator (SE): Benito Saenz
System Designer:
Floodplain Status: Outside
Authorization to Construct: 10/18/2024
Final Inspection: 10/28/2024
Site Evaluation Date: 08/06/2024
Soil Classification: 0.25
Gravel (measured by SE): 5 %
Drinking Water Source: Private Water Supply

Tank GPS : N °
W °

SOIL DESCRIPTION

0-7 ft: Class II Soft Caliche (0.25 Gal/Day/sqFt)*
ft:
0-7 ft: Class II Soft Caliche (0.25 Gal/Day/sqFt)
ft:

Well GPS: N °
W °

Proposed Improvement: Office & Shop
Number of Bedrooms:
Number of Employees/Spaces: 15
Maximum Permitted Daily Flow: 180 gallons per day
Treatment Type: Septic
Primary Tank Volume: 1000 Gallons
Clarifier Tank Volume: Gallons
Pump Tank Volume: Gallons
Tank Manufacturer:
Disposal type: Leaching Chambers
Panel Length: 5.0 feet
Drainfield Length: feet
Drainfield Width: feet

Additional Requirements:

Brandon Vaughn,

Agency

10/28/2024

Date