






	ST. LUCIE COUNTY WATER & WASTEWATER CONSTRUCTION STANDARDS	SEWER SERVICE CLEANOUT		ST. LUCIE COUNTY WATER & WASTEWATER CONSTRUCTION STANDARDS	SEWER CLEANOUT ASSEMBLY		ST. LUCIE COUNTY WATER & WASTEWATER CONSTRUCTION STANDARDS	SEWER SERVICE CLEANOUT		ST. LUCIE COUNTY WATER & WASTEWATER CONSTRUCTION STANDARDS	SANITARY SEWER LATERAL DETAIL		ST. LUCIE COUNTY WATER & WASTEWATER CONSTRUCTION STANDARDS	MANHOLE FRAME AND COVER		
DATE APPROVED: DECEMBER 2019 DRAWING NUMBER: S-2			DATE APPROVED: DECEMBER 2019 DRAWING NUMBER: S-2B			DATE APPROVED: DECEMBER 2019 DRAWING NUMBER: S-2			DATE APPROVED: DECEMBER 2019 DRAWING NUMBER: S-1			DATE APPROVED: DECEMBER 2019 DRAWING NUMBER: S-3				
NOTES: 1. MANHOLES SHALL BE DESIGNED IN ACCORDANCE WITH ASTM C478. 2. CONNECTIONS AND GROUTING IN MANHOLE NOT SHOWN. SEE DRAWINGS FOR PIPE SIZE, LOCATIONS AND INVERTS. 3. PAINT OUTSIDE OF MANHOLE WITH TWO COATS OF COAL TAR EPOXY (BITUMASTIC 50) 4. LINE INSIDE OF MANHOLE WITH AN APPROVED LINING MATERIAL. 5. ALL PIPE PENETRATIONS SHALL BE PRECAST.			NOTES: 1. ALTERNATE LIFT STATION LAYOUTS WILL BE CONSIDERED BY THE DISTRICT ON A CASE-BY-CASE BASIS.			NOTES: 1. ALL ABOVE GRADE PIPING SHALL BE BRASS. FITTINGS SHALL BE BRONZE. 2. ALL JOINTS SHALL BE THREADED. 3. MIN. 24" CLEARANCE BETWEEN RPZ BACKFLOW PREVENTER AND CONTROL PANEL REQUIRED. 4. THREADED AREAS OF CORPORATION STOP AND OTHER FITTINGS SHALL BE SPIRAL WRAPPED WITH TWO WRAPS OF TEFLON TAPE.										
	ST. LUCIE COUNTY WATER & WASTEWATER CONSTRUCTION STANDARDS	STANDARD PRECAST MANHOLE DETAIL		ST. LUCIE COUNTY WATER & WASTEWATER CONSTRUCTION STANDARDS	TYPICAL LIFT STATION PLAN (SMALL)		ST. LUCIE COUNTY WATER & WASTEWATER CONSTRUCTION STANDARDS	WASH-DOWN HYDRANT AT LIFT STATION								
DATE APPROVED: DECEMBER 2019 DRAWING NUMBER: S-5			DATE APPROVED: DECEMBER 2019 DRAWING NUMBER: S-14			DATE APPROVED: DECEMBER 2019 DRAWING NUMBER: S-21										

ISSUE	DATE	COMMENTS