



## ON-SITE WASTEWATER TREATMENT SYSTEM PERMIT

316 North Park Ave., Room 230

Helena, MT 59623

406-447-8351

Fax: 406-447-8398

publichealth@lccountymt.gov

www.LewisAndClarkHealth.org

**PERMIT NUMBER:** SEPN2023-173

**STATUS:** APPROVED

### PARCEL/PERMIT INFORMATION

OWNER: SITE ADDRESS: GEOCODE:	WELLENSTEIN CONNIE J 4775 YORK RD 05199634301100000		
APPLICATION DATE: ISSUED DATE: APPROVAL DATE:	08/23/23 10/12/23 11/06/23	APPLICANT: SANITARIAN: APPROVED BY:	JACK CLARK BETH NORBERG BN
CERTIFIED INSTALLER: CELL: PHONE:	ROBERT DONAT (406) 498-8248	NON CERT. INSTALLER: CELL: PHONE:	

### SYSTEM INFORMATION

SYSTEM TYPE: SYS. SUB TYPE: SOIL TYPE: NO. BEDROOMS	SEPTIC NEW STANDARD V N/A	TYPE: SYSTEM: APP RATE: NO. PEOPLE SERVED:	COMMERCIAL INDIVIDUAL .4 gpd/ft <sup>2</sup> 24	GAL/DAY: 312
NOTES:	System to serve commercial shop, no more than 24 users per day.			

### MINIMUM CONSTRUCTION REQUIREMENTS

TANKS:	Unless specified, all tanks shall be equipped with an effluent filter and risers to grade.			
	SEPTIC TANK 1 SIZE (Gal.)	1500	SEPTIC TANK 1 MATERIAL	Concrete or other approved material
	SEPTIC TANK 2 SIZE (Gal.)	0	SEPTIC TANK 2 MATERIAL	
	DOSE TANK 1 SIZE (Gal.)	0	DOSE TANK 1 MATERIAL	
	DOSE TANK 2 SIZE (Gal.)	0	DOSE TANK 2 MATERIAL	
	HOLDING TANK SIZE (Gal.)	0	HOLDING TANK MATERIAL	
NOTES:	Provide at least 10 feet schedule 40 PVC pipe leading into and out of the septic tank.			
PUMP:	No	PUMP TYPE:	N/A	
NOTES:	Pressure-distribution can be used if the site cannot accommodate grade and/or fitting the primary and replacement area.			
MEDIA FILTER:	MEDIA 1 TYPE:	N/A	MEDIA 2 TYPE:	N/A
NOTES:				
DRAINFIELD:	TYPE:	STANDARD GRAVELLESS	SIZE: 293 - LINEAR FEET	
	TRENCH WIDTH:	24 INCHES	TRENCH DEPTH:	24-36" MAX
NOTES:				
DISTRIB. BOX:	IF NEEDED	OTHER DISTRIBUTION:		
NOTES:	Use a D-Box if there will be an uneven number of laterals and/or the slope at the drainfield is greater than or equal to 4%. D-Box must be set back at least 10 feet from the drainfield.			

### CONDITIONS AND SPECIAL REQUIREMENTS

Place drainfield within 25 feet of test hole location. Maintain all required setbacks and replacement area.

This system shall be installed in accordance with current Lewis & Clark Public Health Department's rules governing the on-site treatment of wastewater, and the minimum construction requirements and special requirements provided for in this permit. This permit is issued, based on the information provided on the permit application. If any of this information is found to be incorrect, or if the system is not installed as provided for, this permit shall be rendered null and void.

The system may not be backfilled without prior approval of the Department or as provided for Certified Installers. A copy of this permit shall be posted in a conspicuous spot at the construction site until permission is given to backfill the system.

This permit will expire one (1) year after the date of issuance. If your system has not been installed prior to the expiration of this permit you will have to reapply and meet the current standards at that time.