

ATTENTION OWNER: Confidentiality  
Privilege Notice on Reverse Side

STATE OF TEXAS  
WATER WELL REPORT

1) OWNER: THORSON, JAMES ADDRESS: GENERAL DELIVERY CITY: FREDERICKSBURG STATE: TX ZIP: 78624-

2) ADDRESS OF WELL: 5)  
County: GILLESPIE GRID # 57-50-1  
Street or RFD: .7 MILES DOWN OLD SAN ANTONIO ROAD FROM HWY 290  
City, State, Zip code: FREDERICKSBURG, TX 78624-

3) TYPE OF WORK: NEW WELL 4) PROPOSED USE: DOMESTIC  
If Public Supply well, were plans submitted to the TNRCC?

6) WELL LOG: 00802	DIAMETER OF HOLE		7) DRILLING METHOD:	8) BOREHOLE COMPLETION:		
	DIAMETER	FROM	TO		FROM	TO
DATE DRILLING:	8.50	0	78	AIR HAMMER	STRAIGHT WALL	N
STARTED: 11/19/97	6.75	78	103		IF GRAVEL...	FROM FT. TO FT.
COMPLETED: 11/19/97	6.00	103	263		FROM	FROM FT. TO FT.

CASING, BLANK PIPE, AND WELL SCREEN DATA:

DIA	NEW/USED	DESCRIPTION	FROM	TO	GAGE CASING SCREEN
6	N	PLASTIC SOLID	0	82	.280

GEOLOGICAL DESCRIPTION:

FROM	TO	DESCRIPTION
0	1	BROWN TOPSOIL
1	6	RED CLAY
6	26	BROWN SAND AND GRAVEL
26	43	RED CLAY
43	50	BROWN SAND <i>Ham</i>
50	68	RED CLAY
68	205	WHITE AND RED LIMESTONE
205	231	GRAY LIMESTONE <i>Ellen</i>
231	263	WHITE AND RED LIMESTONE

WATER DEPTH/YIELD:

FROM	TO	YIELD
87	88	2 GPM
90	91	5 GPM
94	95	2 GPM

9) CEMENTING DATA:  
Cemented from 0 FT. TO 78 FT. No. of Sacks Used 5  
FT. TO FT.  
Method used: GRAVITY CEMENTED  
Cemented by: L & L DRILLING CO.  
Distance to septic field lines: 400 ft.  
Method of verification of above distance: ESTIMATED

10) SURFACE COMPLETION:  
PITLESS ADAPTOR USED

11) WATER LEVEL:  
STATIC LEVEL : 77 FT. DATE: 11/19/97  
ARTESIAN FLOW: GPM. DATE:

12) PACKERS:	TYPE	DEPTH

13) TYPE PUMP: 14) WELL TEST:  
JETTED  
DEPTH TO PUMP: YIELD: 120 GPM WITH FT DRAWDOWN AFTER HRS

15) WATER QUALITY: CHEMICAL ANALYSIS MADE  
TYPE OF WATER: DEPTH OF STRATA: 21 GRAINS OF HARDNESS  
NO STRATA OF UNDESIRABLE WATER PENETRATED 790 T.D.S.

COMPANY NAME: L & L DRILLING CO. WATER WELL DRILLER'S LICENSE NO.: 1595 FOR TWC USE ONLY  
ADDRESS: DRAWER 217 CITY: HYE, STATE: TX ZIP CODE: 78635 WELL NO. \_\_\_\_\_  
LOCATED ON MAP \_\_\_\_\_

I HEREBY CERTIFY THAT THIS WELL WAS DRILLED BY ME (OR UNDER MY SUPERVISION) AND THAT EACH AND ALL OF THE STATEMENTS HEREIN ARE TRUE TO THE BEST OF MY KNOWLEDGE AND BELIEF. I UNDERSTAND THAT FAILURE TO COMPLETE ITEMS 1 THRU 15 WILL RESULT IN THE LOG(S) BEING RETURNED FOR COMPLETION AND RESUBMITTAL.

(signed) *Dregan A. Smith*  
LICENSED WATER WELL DRILLER

(signed) \_\_\_\_\_  
(REGISTERED DRILLER TRAINEE)

PCI-013  
~~PI-00002~~  
R-012

OWNER: THORSON, JAMES

ADDRESS: GENERAL DELIVERY

CITY: FREDRICESBURG

STATE: TX ZIP: 78624-

166	167	6 GPM
189	190	5 GPM
197	198	7 GPM
234	235	8 GPM
244	250	85 GPM

WELL JETTING INFORMATION:

JETTED AT	YIELD
120 FT.	20 GPM.
140 FT.	38 GPM.
160 FT.	50 GPM.
180 FT.	75 GPM.