

RECEIVED

NOV 8 1984

JACK 585-349/1W-15db

STATE OF OREGON WATER WELL REPORT (as required by ORS 537.765)

PLEASE TYPE OR PRINT IN INK WATER RESOURCES DEPT. SALEM, OREGON

(for official use only)

(1) OWNER:

Name VIOLA FALSKE Address 6138 BLACKTHORN City LAKEWOOD State CA.

(2) TYPE OF WORK (check):

New Well [X] Deepening [] Reconditioning [] Abandon []

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Air [X] Driven [] Rotary Mud [] Dug [] Bored []

(4) PROPOSED USE (check):

Domestic [X] Industrial [] Municipal [] Irrigation [] Thermal: [] Withdrawal [] ReInjection [] Other: Piezometric [] Grounding [] Test []

(5) CASING INSTALLED:

Steel Threaded [X] Plastic Welded [X] 6" Diam. from +1 ft. to 29 ft. Gauge 230

LINER INSTALLED:

Steel Threaded [] Plastic Welded []

(6) PERFORATIONS:

Size of perforations in. by Perforated? [] Yes [X] No in. perforations from ft. to ft.

(7) SCREENS:

Well screen installed? [] Yes [X] No Manufacturer's Name Type Model No. Diam. Slot Size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level Was a pump test made? [] Yes [X] No If yes, by whom? gal./min. with ft. drawdown after hrs.

(9) CONSTRUCTION:

Special standards: Yes [] No [X] Well seal—Material used PORTLAND CEMENT Well sealed from land surface to 29 ft. Diameter of well bore to bottom of seal 10 in. Diameter of well bore below seal 6 in. Amount of sealing material 11 sacks [X] pounds [] How was cement grout placed? PRESSURE GROUT TREMIE PIPE Was pump installed? NO Type HP Depth ft. Was a drive shoe used? [X] Yes [] No Plugs Size: location ft. Did any strata contain unusable water? [] Yes [X] No Type of Water? depth of strata Method of sealing strata off Was well gravel packed? [] Yes [X] No Size of gravel: Gravel placed from ft. to ft.

(10) LOCATION OF WELL by legal description:

County JACKSON NW 1/4 SE 1/4 of Section 15 Township 34 Range 1W WM. Tax Lot 1900 Lot Block Subdivision MAILING ADDRESS OF WELL (or nearest address) 22300 HWY 62, SHADY COVE, OR.

(11) WATER LEVEL of COMPLETED WELL:

Depth at which water was first found 45 ft. Static level 25 ft. below land surface. Date 10-29-84 Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 6" Depth drilled 62 ft. Depth of completed well 62 ft. Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

Table with columns: MATERIAL, From, To, SWL. Rows include SOIL, BROWN; BOULDERS, SMALL; CLAYSTONE, BLUE; CLAYSTONE, BROWN; CLAYSTONE, BLUE; 10" SURFACE CASING; ALSO PUSHED CEMENT FROM INSIDE CASING TO BOTTOM OF SEAL.

Date work started 10-29-84 /completed 10-29-84 Date well drilling machine moved off of well 10-29-1984

(unbonded) Water Well Constructor Certification (if applicable):

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Joaquin Medina Date 10-29, 1984

(bonded) Water Well Constructor Certification:

Bond U 0951162 Issued by: UNITED PACIFIC (number) (Surety Company Name) On behalf of MARTINSON WELL DRILLING, INC. (type or print name of Water Well Constructor)

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief:

(Signed) Ronald J. Martinson (Water Well Constructor)

(Dated) 10-30-84

NOTICE TO WATER WELL CONSTRUCTOR The original and first copy of this report are to be filed with the

WATER RESOURCES DEPARTMENT, SALEM, OREGON 97310 within 30 days from the date of well completion.

SP*46866-690

RECEIVED

JACK 562

345/1W-15bc

STATE OF OREGON WATER WELL REPORT (as required by ORS 537.765)

DEC - 9 1987

WATER RESOURCES DEPT SALEM, OREGON

(1) OWNER:

Name Mrs Branson Address 21901 Hwy 62 City Shady Cove State OR Zip

(2) TYPE OF WORK:

New Well Deepen Recondition Abandon

(3) DRILL METHOD

Rotary Air Rotary Mud Cable Other

(4) PROPOSED USE:

Domestic Community Industrial Irrigation Thermal Injection Other

(5) BORE HOLE CONSTRUCTION:

Special Construction approval Yes No Depth of Completed Well 160 ft. Explosives used Type Amount

Table with columns: HOLE Diameter, From, To, SEAL Material, From, To, Amount sacks or pounds

How was seal placed: Method A B C D E Backfill placed from ft. to ft. Material Gravel placed from ft. to ft. Size of gravel

(6) CASING/LINER:

Table with columns: Diameter, From, To, Gauge, Steel, Plastic, Welded, Threaded

Final location of shoe(s) 55'

(7) PERFORATIONS/SCREENS:

Perforations Method Screens Type Material

Table with columns: From, To, Slot size, Number, Diameter, Tele/pipe size, Casing, Liner

(8) WELL TESTS: Minimum testing time is 1 hour

Pump Bailer Air Flowing Artesian Yield gal/min Drawdown Drill stem at Time

Temperature of water Depth Artesian Flow Found Was a water analysis done? Did any strata contain water not suitable for intended use? Salty Muddy Odor Colored Other Depth of strata:

(9) LOCATION OF WELL by legal description:

County Jackson Latitude Longitude Township 34 N or S, Range 1W E or W, WM. Section 15-13c Tax Lot 1900 Lot Block Subdivision Street Address of Well (or nearest address) Same

(10) STATIC WATER LEVEL:

30' ft. below land surface. Date 11-19-87 Artesian pressure lb. per square inch. Date

(11) WATER BEARING ZONES:

Table with columns: From, To, Estimated Flow Rate, SWL

(12) WELL LOG:

Table with columns: Material, From, To, SWL

Date started 11-18-87 Completed 11-19-87

(unbonded) Water Well Constructor Certification:

I certify that the work I performed on the construction, alteration, or abandonment of this well is in compliance with Oregon well construction standards. Materials used and information reported above are true to my best knowledge and belief.

Signed [Signature] WWC Number 1449 Date 12-3-87

(bonded) Water Well Constructor Certification:

I accept responsibility for the construction, alteration, or abandonment work performed on this well during the construction dates reported above. all work performed during this time is in compliance with Oregon well construction standards. This report is true to the best of my knowledge and belief.

Signed [Signature] WWC Number 1379 Date 12-4-87