



HOLES FIRE-RATED BARRIER
 2x6 wood studs @ 16" o.c. shall be provided to underside of wood roof deck with sound attenuation batt insulation full height w/ 3/8" type 'X' gypsum board - 48" width - horizontally applied either vertically or horizontally. The wall shall be finished with 1/2" gypsum board. The wall shall be 100 square inches and be clear tempered safety glass.

GENERAL DOOR/RAMPE NOTE:
 All doors and frames within 1-hour fire-rated barriers shall be 45-minute fire-rated and bear UL designation. Do not use doors and including fire-rated doors - glass shall be limited to 100 square inches and be clear tempered safety glass.

NON-RATED INTERIOR WALLS
 2x4 wood studs @ 16" o.c. shall be provided to 6' above finished ceiling with sound attenuation batt insulation full height w/ 3/8" type 'X' gypsum board.

WAREHOUSE
 101
 12 occupants
 FINISH FLOOR
 ELEV 100'-0"

NOTE: Interior walls at SHOP III and MECH 110 shall be extended up to underside of trusses, etc.

DRYER ENCLOSURE SEE SITE PLAN & ELEVATIONS

SHOP III
 11 occupants
 FINISH FLOOR
 ELEV 100'-0"

MECH 110
 DRYER BY OWNER

OPEN OFFICE 104
 12 occupants
 FINISH FLOOR
 ELEV 100'-0"

OFFICE 104

OFFICE 103

OFFICE 102

OFFICE 101

MAINT 105
 ENTRY 102
 MEN 112
 WOMEN 113

MALL-INTD LAV. 34"
 36" GRAB BAR
 25" GRAB BAR (HORIZ) W/B
 VERT GRAB BAR
 VANITY COUNTER
 SINK, 34"
 36" GRAB BAR
 42" GRAB BAR
 VERT GRAB BAR
 VERT GRAB BAR

EXIT LIGHT TYPE
 INDUAL EGRESS
 LIGHT HEADS
 CATCH
 BASIN

4x12' CONC APRON

4x12' CONC APRON