

MOORE'S TANK SERVICES

Underground Storage Tank Certification of Removal

This is to certify that Moore's Tank Services, Inc. removed the below referenced residential underground storage tank (UST) using the practices and procedures outlined in Bulletin 95-1B, example "B" of the State of New Jersey, Department of Community Affairs, Division of Codes and Standards.

Summary of work performed: Removed heating oil from UST, Tank excavated, cut open, sludge removed and inside cleaned. UST was removed, inspected and approved by the **Monroe Twp Fire Inspector**. There was no evidence of discharge. Two soil sample were taken directly under the tank along the centerline to confirm that the tank did not leak. The tank was recycled at a proper recycling facility. The residual sludge and/or water were disposed at a licensed facility.

Date of Removal: 7/12/2024

Permit # 20240968

Owner: **800 SBHP LLC**

Site Address: **800 South Black Horse Pike**

Town: State, Zip Monroe Twp, NJ 08096

County: Gloucester

Tank Capacity: 1000 Gallons

Tank Size: **4 feet Diameter x 10 feet long**

Soil sample results: **SOIL SAMPLE UNDER THE TANK ON THE CENTERLINE RESULTS WERE "ND" MEANING NO DETECTIONS.**

This confirms no oil was present in the soil and the NJDEP did not have to be notified.




James Moore

NJDEP Certification No.0019277

Moore's Tank Services, Inc. is NJDEP certified to perform closure and subsurface evaluation.
Certification No. US01096

3459 Norwood Ave., Pennsauken NJ 08109 Tel: (856) 662-2002 Fax: (856) 662-8550



Technical Report

prepared for:

Moore's Tank Services Inc.

3459 Norwood Ave

Pennsauken NJ, 08109

Attention: Jim Moore

Report Date: 07/18/2024

Client Project ID: 800 Black Horse Pike

York Project (SDG) No.: T4G0274

Precision Analytical Services

NJ Certificate No. 15001

MA Certificate No. NJ1364

2161 Whitesville Road, Toms River, NJ 08755


www.YORKLAB.com

Precision Testing Laboratories

NJ Certificate No. 15005

(732) 905-5000

EnvironmentalServices-TomsRiver@yorklab.com



York Analytical Laboratories, Inc.
Cert. No 15001 & 15005
2161 Whitesville Road, Toms River, NJ 08755
Tel. 732-905-5000 Fax. 732-279-4422
environmentalservices-tomsriver@yorklab.com

Analyzed by: York Analytical Laboratories- Toms River

Client:	Moores Tank Services Inc.	York Work Order No:	T4G0274
Client Project:	800 Black Horse Pike	Collection Date/Time:	7/12/24 12:30 pm
		Date Received:	7/16/24 12:00 pm

Analysis: EPH Category 1 by GC/FID				Reference Method: NJDEP EPH Rev 3.0				
Prep Method: SW-846 3546 (GC)				Matrix: Soil				
Lab ID	Client ID	Parameter	Result	Flag	RL	MDL	Units	Analyzed
T4G0274-01	PTR1 5.5-6	C9 to C28 Hydrocarbons (EC Range)	ND		20.6	20.6	mg/kg dry	07/17/2024 18:51

Analysis: EPH Category 1 by GC/FID		Reference Method: NJDEP EPH Rev 3.0						
Prep Method: SW-846 3546 (GC)		Matrix: Soil						
Lab ID	Client ID	Parameter	Result	Flag	RL	MDL	Units	Analyzed
T4G0274-02	PTR2 5.5-6	C9 to C28 Hydrocarbons (EC Range)	ND		18.9	18.9	mg/kg dry	07/17/2024 19:11

Vinicius Bandeira
Laboratory Director

FORM IV**PREPARATION BATCH SUMMARY
SM 2540G**Laboratory: York Analytical Laboratories- Toms RiverSDG: T4G0274Client: Moores Tank Services Inc.Project: 800 Black Horse PikeBatch: T24G185 Batch Matrix: SoilPreparation: % Solids Prep

SAMPLE NAME	LAB SAMPLE ID	LAB FILE ID	DATE PREPARED	OBSERVATIONS
Duplicate	T24G185-DUP2	T24G185_20240718-007	07/17/24 17:15	
PTR1 5.5-6	T4G0274-01	T24G185_20240718-002	07/17/24 17:15	
PTR2 5.5-6	T4G0274-02	T24G185_20240718-003	07/17/24 17:15	