

# SEPTIC SYSTEM PERMIT

FLATHEAD CITY-COUNTY HEALTH DEPARTMENT

Environmental Health Services

723 5th Ave East, Kalispell, MT 59901

Number	97-2824N
Site Eval. Receipt	PrevRev.
Date Issued	10/27/97
Zone	3
Date Recorded	10/14/97

1. Legal Description: Co. Assess. Tr.#    SEC: 24 TWP: 30 RNG: 21  
 Subdiv. Name BRUNNER TRACTS Lot 9 Blk.     
 COS # 1 of 2 Permits Parcel Size 2.004 1.23 acres

✓ 2. William B. Mann Same  
 Legal Property Owner Address and Phone

3. Authorization for: New  Replacement of  Alteration/Repair of  Septic System.

4. Proposed Structure: Conv. Sing. Fam.  Mob. Home  Multi-fam. (specify) Mob. Home

Commercial (specify) Mob. Home Other (specify) Mob. Home

5. No. of Bedrooms 2 or No. of Occupants    Existing Structures   

6. Water Supply: Indiv.  Multi-user  Public (name)    Multi-user Source Well   

#### Evaluator's Comments:

7. Soil Type: Loamy sand over coarse sand & gravel How Determined: Submittal

8. Depth to Groundwater Table/Bedrock 72" How Determined: Submittal

#### System Specifications:

9. Classification 1G Septic Tank Size 1000 gallons (min) Absorption Area 320 ft2

#### 10 Drainfield Description

Use the approved drainfield site as indicated during subdivision review.

Use 160 lineal feet of perforated pipe in 2-foot wide trenches.

Trenches must be NO DEEPER THAN 24 INCHES below the natural ground surface OR sand line trenches with bottom of drainrock no deeper than 36 inches.

Perforated pipe and lateral trench bottoms are to be level.

No single drainfield lateral is to exceed 80 feet from the point of effluent entry from solid pipe.

Plan carefully and be sure of all County septic regulations and construction standards.

Reserve space for 100% replacement drainfield.

800856

10/17/97

Christie Bond, R. S. CB


Date

Signature Authorizing Approval of Permit

\* These requirements establish the minimum specifications for this septic system installation. The permit will be voided and declared invalid if the system is not installed within 12 months for class 1, 2, and 4 or 24 months for class 3 and 5 systems. The issuance of this permit authorizes construction of the septic system and requires the installation comply with the FLATHEAD COUNTY REGULATIONS FOR SEWAGE TREATMENT SYSTEMS (FCRSTS). The permit will be void if the system is not utilized as intended within one year of installation. The property owner is responsible for operating and maintaining the system in accordance with FCRSTS. Failure to comply with these regulations may result in revocation of this permit. This permit does not constitute a design and does not bind or obligate this office to guarantee the performance of the system. This permit shall be given to the installer prior to construction. The owner shall give 24 hours advance notice for the required inspection of the system. Please call 758-5760.

## AYOUT

↑  
N



13

기

Water source developed at time of inspection? YES  NO  Distribution YES  NO

**Disapproved/Date**

## Reason

**Approved/Date**

## Comments

$$160 \text{ LF} \times 2 = 320 \text{ ft}^2$$

Glen  
INSPECTOR'S SIGNATURE

—Name— W. H. L.

Glen O. been  
Instalator