


Analytical test results indicated TPH (C₆-C₁₂), TPH (>C₁₂-C₂₈) and TPH (>C₂₈-C₃₅) levels, in soil and groundwater, less than laboratory sample detection limits (SDLs). The TCEQ Petroleum Storage Tank (PST) program does not have any action level for TPH and is used only to screen for Polynuclear Aromatic Hydrocarbons (PAHs). A PAH analysis was not conducted as it is required only if there is detection in TPH (>C₁₂-C₂₈) and TPH (>C₂₈-C₃₅) ranges above the method quantitation limits (MQLs). Benzene, toluene, ethyl benzene, xylene and MTBE levels, in soil and groundwater, were also below SDLs and/or less than TCEQ's PST program action levels. Consequently, Bandy & Associates, Inc. recommends no further investigation at this time.

We appreciate the opportunity to perform this study. Please call upon us if you have any questions.



Very truly yours,
BANDY & ASSOCIATES, INC.
LPST RCAS00476
TX Reg. No. F-10373

Malathi Krishnan
Malathi Krishnan
Environmental Engineer

S. S. Bandy
S. S. Bandy, Ph.D., P.E.
President
LPST CAPM00572
TX P.E. No. 51575