



Electrical Plan
Sc. 3/16" = 1'-0"

GENERAL NOTES: ELECTRICAL

- A. COORDINATE EXACT LOCATION AND MOUNTING HEIGHT OF ALL POWER SOURCE WIRING IN ACCORDANCE WITH ARCHITECTURAL MILLWORK.
- B. ELECTRICAL CONTRACTOR SHALL VERIFY ALL REQUIREMENTS BEFORE ANY ROUGH-IN IN ORDER TO COORDINATE MANUFACTURER'S DRAWINGS FOR EQUIPMENT LOCATION AND INSTALLATION ACCESSORIES.
- C. COORDINATE RUNS FOR CONDUIT UP IN JOIST AND FOR SUSPENDING REQUIREMENTS IN ACCORDANCE STRUCTURAL PLANS.
- D. COORDINATE EXACT LOCATION OF ALL MECHANICAL EQUIPMENT IN ACCORDANCE MECHANICAL DRAWINGS.
- E. FURNISH DUCT SMOKE DETECTOR FOR RETURN DUCT. COORDINATE EXACT LOCATION IN ACCORDANCE MECHANICAL DRAWINGS.
- F. ALL DEVICES SHOWN ON DRAWINGS ARE SYMBOLIC ONLY. THE ENTIRE FIRE ALARM SYSTEM, SHALL BE IN FULL COMPLIANCE AND MEET ALL CODES AND REQUIREMENTS OF THE LOCAL ADMINISTRATIVE AUTHORITY. ANY MODIFICATIONS REQUIRED TO PROVIDE COMPLIANCE SHALL BE MADE AT NO ADDITIONAL COST TO THE OWNER OR ARCHITECT/ENGINEER.
- G. EQUIPMENT AS FURNISHED BY NOTIFIER, EDWARDS, SILENT KNIGHT OR APPROVED EQUAL SHALL BE ACCEPTABLE FOR EASE OF MAINTENANCE AND PARTS REPLACEMENTS, USE EQUIPMENT OF A SINGLE MANUFACTURER, TO THE MAXIMUM EXTENT POSSIBLE.
- H. COORDINATE EXACT LOCATION OF ISOLATED OUTLETS FOR COMPUTERS WITH OWNER.
- I. ELECTRICAL CONTRACTOR SHALL PROVIDE J-BOX AND CONDUIT FOR H.V.A.C. CONTROLS AND THERMOSTATS. COORDINATE EXACT LOCATION WITH MECHANICAL CONTRACTOR.
- J. COORDINATE LOCATION OF LIGHTS WITH DIFFUSERS AND GRILLES.
- K. COORDINATE EXACT ROUTING OF ALL CONDUIT ABOVE CEILING IN BUILDING. TYPICAL FOR ALL BUILDING EXTERIOR LIGHTING.
- L. VERIFY CEILING TYPES AND COORDINATE WITH FIXTURE TYPE. NOTIFY ENGINEER IF DISCREPANCIES EXIST PRIOR TO ORDERING FIXTURES.
- M. PROVIDE CLEAR VANDAL COVER WITH STOPPER II OPTION FOR ALL FIRE ALARM PULL STATIONS.

KEYED NOTES: POWER

- 1 TIE INTO ROOMS LIGHTING CIRCUIT AND INTERLOCK FAN WITH ROOMS LIGHTS. WIRING SHALL BE 2#12, 1#12G, 1/2" C.
- 2 3/4"x8"HX4"W PLYWOOD TELEPHONE BOARD FINISHED ONE SIDE. PROVIDE GROUND BAR AND TIE INTO ELECTRICAL GROUNDING SYSTEM VIA WIRE #4.

Sheet No: 4.1
Date: 6/19/17

Revision:

Project: COMMERCIAL
Customer: TAICO 88, LLC
Plan: ELECTRICAL PLAN

REMODEL: COMMERCIAL BUSINESS & OFFICE
8565 FM2673
CANYON LAKE, TX 2017

THIS DRAWING IS THE PROPERTY OF MK DESIGN STUDIO. IT IS TO BE USED ONLY FOR THE PROJECT AND SITE SPECIFICALLY IDENTIFIED HEREIN. IT IS NOT TO BE REPRODUCED OR COPIED IN ANY MANNER WITHOUT THE WRITTEN PERMISSION OF MK DESIGN STUDIO. THE USER SHALL BE RESPONSIBLE FOR THE PROTECTION, SECURITY, AND MAINTENANCE OF THIS DRAWING. MK DESIGN STUDIO SHALL NOT BE RESPONSIBLE FOR ANY DAMAGE TO PROPERTY OR PERSONS ARISING FROM THE USE OF THIS DRAWING. THE USER SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS FROM THE LOCAL BUILDING CODES IN THE AREA WHERE THE PROJECT IS TO BE CONSTRUCTED. MK DESIGN STUDIO IS NOT AN ENGINEERING FIRM AND DOES NOT PROVIDE ENGINEERING SERVICES. CONSULT WITH A LICENSED PROFESSIONAL ENGINEER FOR ALL ENGINEERING REQUIREMENTS.

MK
design Studio
design + render + construction
Tel: (956) 569-7293
Email: orlando@mkdesignstudio.com
Web: www.mkdesignstudio.com