

Memorandum

TO: Grant County Planning Department

FROM: Erlandsen

DATE: August 9, 2022

SUBJECT: Moses Lake Water system


Water Rights

The current Moses Lake Water System Plan (WSP) table 2-4 shows that in 2012 the annual city consumption was 9,576 acre-feet and by 2034 that consumption demand would go up to 18,348 acre-feet.

In a quick review of water use in the city and water rights and expected Comprehensive plan Growth expected, the following was found by looking at current City of Moses Lake published documents on water usage:

- The 2021 water use efficiency shows that the city produced a total of 3,083 Million gallons of water = 9,462 ac-ft of water annually.
- The 2021 comprehensive plan estimated population growth within the city limits to the year 2038 to be 11,400 people = 4,560 SFR = 1,788 ac-ft of water annually.
- As mentioned in previous Council meeting testimony and Comprehensive plan suggest the city is adding a minimum 804 ac-ft from transfers.

Table 2-6 of the WSP shows the city has domestic water rights for 25,694 acre-feet yet Ecology adjusted the current water rights to 15,400 acre-feet. Per the city's current WSP that the city has adequate water rights for UGA plat developments.



Based on current use and comprehensive planning out to year 2038 the city of Moses Lake has around 4,154 Acre-Feet of water for domestic use available in the UGA areas.

$$(14,600 + 804 - 9462 - 1,788 = 4,154 \text{ Acre-feet})$$

As part of the Development Agreement, the project will be bringing additional water rights to the table for COML Water system

System Description and Analysis in the Moses Lake Water System Plan:

Moses Pointe area is evaluated as part of the Central pressure zone. Currently, the area has experienced limited development in the lower elevations of the project. Therefore, the Central zone provides adequate pressure and service. Once the development reached 225 ERU's, the Moses Pointee reservoir was to be placed into service. When the reservoir is built the Moses Pointee Booster Pump Station and Well #19 will have a storage facility to pump into and the Moses Pointee area will become a separate pressure zone.

It is our understanding that the city is about to go out to bid on the Moses Pointee water tank project. Our review of the water tank size is based on the tank that was designed in 2017 under ML public works project file A527J. (image below)





Figure: Moses Pointee Booster Pump Station.



Also part of the Moses Pointee water system is the Moses Pointe Boster Pump. The pump station consists of three 600 gpm 15 hp pumps and one 125 gpm 3 hp jockey pump. Two of the 600 gpm pumps are on a backup generator system. As part of the water tank standby storage calculation, the booster pump can supply 1,200 gpm to the Moses Pointee water system.

Urban growth Area north of road 4 Northeast for your review is broken down into the following areas in Table 1





Figure: Mae Valley UGA – purple shade

Table 1

UGA Region	Current Lot #s (SFR Equivalent)	Possible future lot # with allowed density
Lots west of RD F NE	0	2672
Lots east of Paradise Pointe	0	320
Lots in Paradise Pointe Plat UR-3	612	612
Lots in UGA North UR-2	0	3540
Lots south of RD 5 NE	0	380
Moses Pointe UGA	217	641

For the Paradise Pointe plat for zone UR-3 the current build-out at Moses Pointe, the total number of ERUs that will be served is 829. At current Grant County zoning, the full UGA has a total possible density of 6,724 ERUs. For the water tank sizing, we looked at a conservative full building out for Moses Pointe and both Paradise Pointe plats Division 1 and 2 of 3,352 ERUs.



Washington State Water System Design Manual on Standby Storage says:

4.4.3.2 ERUs Based on Standby Storage

Standby storage is a volume of finished water a water system reserves to maintain a certain level of service if one or more permanent or seasonal source of supply becomes partially or completely unavailable for use.

Water systems must provide standby storage in an amount necessary to maintain reliable water service (WAC 246-290-235(3) and WAC 246-290-420). We recommend SB volume equal to the MDD for the pressure zone(s) served (i.e., $T_d = 1$ day) and adjust SB volume based on redundant sources and other factors (see Section 7.1.1.3). To satisfy WAC 246-290-235 and -420, we recommend that water systems provide a minimum standby storage volume of 200 gpd per ERU regardless of such factors.

If well 19 were to go down the system can be supplied by the Moses Pointee water system Boster Pump. Two of the 600 gpm pumps are on a back-up generator system. As part of the water tank standby storage calculation the booster pump can supply 1,200 gpm to the Moses Pointee water system and thereby no standby storage is required.

The state recommendation at a minimum standby storage of a minimum of 200 gpd per ERU the standby storage would be 670,400 gallons. Based on the 2007 tank design the lowest pressure at Moses Pointee around the tank will be 26 PSI, in the two UGA Paradise Pointe plat would see a minimum pressure of 55 PSI.

Fire storage and Standby can normally be combined in the same area of the tank, especially since the backup booster pumps voids standby storage as a requirement. Planning for 3,000 GPM commercial need fire flow for 3 hours, 540,000 gallons of storage is required. The 2007 tank can provide this with the lowest pressure near the tank being 29 PSI and for the UGA plat the minimum fire pressure would be 59 PSI.

WORKSHEET 4-1
ERU Capacity Summary

Specific Single-Family Residential Connection Criteria (measured or estimated demands)

Average Day Demand (ADD): 350 gpd/ERU Maximum

Day Demand (MDD) 787.5 gpd/ERU

Water System Connections Correlated to ERUs			
Service Classification	Total MDD for the classification, gpd	Total # Connections in the classification	ERUs
Residential			
Single-family	787.5	3352	3352
Multifamily			
Nonresidential			
Industrial			
Commercial			
Governmental			
Agricultural			
Recreational			
Other (specify)			
DSL	400	N/A	
Other (identify)			
Total existing ERUs (Residential + Nonresidential + DSL + Other) = 3352			

Service Capacity as ERUs and Gallons Per Day		
Water System Component (Facility)	ERU Capacity for Each Component	GPD Capacity for Each Component
Source(s)		
Mae Valley Booster	6,583	2,304,000
Well 19	3,394	1,188,000
Treatment		
Equalizing Storage	3352	337,357
Standby Storage	200	0
Transmission	1700 (@ 5 FPS)	3,400 FPS
Water Rights (Qa and Qi)		825 GPM
Other (specify) Fire Storage	3000 gpm	540,000
Water System Service Capacity (ERUs) = 3352		
(based on the limiting water system component shown above)		

Notes:

- Capacity determinations are only for existing facilities that are operational for the water system.
- Not shown above are distribution system limitations (Section 4.5.4) on ERUs because these are location-specific within the distribution system. These limits not expected to limit the ERU capacity of the entire water system.

Tank storage Calculations for the 2007 Moses Pointee tank can be found in Appendix A.

Based on those Calculations the tank's Equalizing, standby – fire suppression storage system pressure will be as follows.

The lowest operation pressure at the bottom of the equalizing storage calculations is 44 PSI near the tank, and 73 PSI at the two Paradise Pointe UGA plats. Standby and Fire flow the required minimum pressure is 20 PSI. The system near the tank will see a minimum of 24 PSI at the bottom of the state recommend standby storage, even though not required. Fire flow storage at 3,000 GPM for 3 hours will see a minimum pressure of 28 GPM.

Tank System	Moses Pointe	
	1126 Tank Base ELEV	service grades
	125 Tank Height	1122 heighest point
	50 Tank Diameter	1053 lowest point
	14726.25 Gallons per foot	
	1251 Overflow ELEV	service pressures
	1250.5 Operation ELEV	
	4 Operation Depth	53.9 low psi
	58905 Operation Vol Gal	83.8 high psi
	1246.5 Operation Bot ELEV	
	337,357 ES Volume Gal	
	1246.5 ES top ELEV	
	22.91 ES Tank Depth	44.0 low psi
	1223.59 ES bottom ELEV	73.8 high psi
	0.00 SB Sourse Vol Gal	
	0.00 Sbtms tank Depth	44.0 low psi
	1223.59 Sbtms Bottom ELEV	73.8 high psi
	670,400 SB WA Req Vol Gal	
	45.52 Sbtms tank Depth	24.3 low psi
	1178.07 Sbtms Bottom ELEV	54.1 high psi
	540,000 FSS Vol Gal	
	36.67 FSS tank Depth	28.1 low psi
	1186.92 FSS Bottom ELEV	58.0 high psi
	1,007,757 Total Tank Stg Vol	
	68.43 tank Storage	24.3 low psi
	1178.07 Bottom ELEV	54.1 high psi

APPENDIX A

WASHINGTON STATE DEPARTMENT OF HEALTH

CHAPTER 6 WATER SYSTEM TANK STORAGE DESIGN STANDARDS CALCULATIONS

PHYSICAL CAPACITY ANALYSIS

Chapter 6

Largets Lot size	0.1	acres
Number of ERUs	3352	#
GPD per ERU	350	gpd
MDD Factor (range 1.5 -3)	2.25	

Residential demands	WSDM w/ IRR		WSDM w/o IRR	Peak Hour Demand Coef		
Average Daily Demand (ADD)	350	GPD	200	ERUs	C	F
Maximum Daily Demand (MDD)	787.5	GPD	450	15-50	3	0
Maximum Month Ave Day (MMAD)	1299.375	GPD	585	51-100	2.5	25
Peak Hour Demand (PHD)	3074	GPM	1765	101-250	2	75
				251-500	1.8	125
				>500	1.6	225
Non-Residential demands						
Average Daily Demand (ADD)						
Maximum Daily Deman (MDD)						
Maximum Month Ave Day (MMAD)						
Peak Hour Demand (PHD)						

Distribution System Leakage

Dist Sys Leakage (DSL)	400	gpd
Persent (DSL)	13%	
Total H2O Produced (TP)	3000	gpd
Auth Consumption (AC)	2600	gpd

Individual Source Capacity

Source 1

Total Vol (Vj)	2,304,000.00	gpd	CENTRAL
Delivery Rate source (Qj)	1600	gpm	
Time flow deliverd (tj)	1440	min	

Source 2

Total Vol (Vj)	1,188,000.00	gpd	WELL 19
Delivery Rate source (Qj)	825	gpm	
Time flow deliverd (tj)	1440	min	

Source 3

Total Vol (Vj) 0 gpd
Delivery Rate source (Qj) 0 gpm
Time flow deliverd (tj) 1440 min

Total Source Capacity 3,492,000.00 gpd

ERU Based on ADD

Number of ERUs (N) 9977 #
Annual Volume all sources(Va) 1274580000 Gal/yr

ERU Based on MDD

Number of ERUs (N) 4434 #
Total Source Volume per day (Vd) 3492000 Gal/day

Capacity Based on Storage

Equalizing Storage (ES) 337,357.03 gal
Total Pump Source Cap (Qs) 825 gpm
Number of ERUs (N) 3352 # Chng C & F

Standby Storage (SBtms) (1,633,600.00) gal With single source down
Average Daily Demand (ADD) 200 gpm WSDM 4.4.3.2
ERUs 3352 #
Total Pump Source Cap (Qs) 2425 gpm
Largest Capacity Source (Ql) 825
Days of Standby 1 days
Time well Source pump TM 1440 min

Total Standby Storage (SBt) 670,400 With all sources down
Standby Storage reliability (Sbl) 200 gal/ERU
Time SBt is be used 1 days
Number of ERUs (N) 3352 #

Total Fire Suppression Storage (FSS) 540,000.00
Needed Fire Flow (NFF) 3000 gpm
Duration of (NFF) 3 hours
Duration of (NFF) 180 min
System Source Contribution 0 gpm

Capacity Related Storage (CRS) 1,007,757 gpd
Max Daily Demand (MMD) 787.5 gpd
Number of ERUs (N) 4077

Hot Sheet-Seller/Buyer Information

Address: 4296 Sun Drive , Moses Lake, WA

MLS: 2305934 **Contact Name:** Alex and Maria

Comments: _____

Closed Date: / /2025 or sooner

Listing/Seller **Sold/Buyer** **Completed**

Listing Paperwork		Mutual Acceptance Date		MLS#	
Signed installed		E/M Deposit Date		Cd Turned in to Office	
Photos		Inspection Response Date		Record on Xmas List	
Lock Box Shackle Set up		Septic Pump Date		Send Thank you card	
Sign Removal		Form 17 Sent/Received		Gift Given/Sent	
Notable feature sheet		Water Test		Back up text messages	
Title Company		Buyer Brokage Agreement			
Commission Rate		Title Company			
Set up Showing time					
Upload:	Title report FIRPTA				
Legal Septic Well Info ~ Map	CCR's Notable features				

If Referral is due please fill out below			
Company:	Agent:		
Address:	City:		
Referral Amount:			
Where did lead come from:			
Referral- In Office <input type="checkbox"/>	Floor Call <input type="checkbox"/>		
Referral- Other Office <input type="checkbox"/>	Sign Call <input type="checkbox"/>		
Referral- Personal/Client <input type="checkbox"/>	Printed Ad <input type="checkbox"/>		
Zillow <input type="checkbox"/>	Windermere.com <input type="checkbox"/>		
Facebook / Instagram <input type="checkbox"/>	Networking Group <input type="checkbox"/>		
Personal Lead <input checked="" type="checkbox"/>	Windermere Relo <input type="checkbox"/>		
Past Client <input type="checkbox"/>	Other FSBO <input type="checkbox"/>		