

THE COUNTY OF LIBERTY
On-Site Sewerage Facility Department

2103 Cos Street
Liberty, Texas 77575
Phone 936-336-4558 Cleveland (281) 593-0405

Final Inspection: 3/13/24

License No: 2024-0583

Applicant: JOSE & NORMA BOTELLO

Mailing Address: 2326 SANDYDALE LANE, HOUSTON, TEXAS 77039

71 CR 370
Loc of Const: SPLENDORA, TEXAS 77372 PID # 143302

Liquid Capacity Of:

Pre-Treatment Tank 500

Aerobic Tank 500

Pump Tank 750

Check One: Home: _____ Mobile Home: X Other: _____

No. Bdrms: 3 GALLONS per Day: 240

Type of System: Aerobic-Cleanstream

Number of Sprinklers 4 Radius of Sprinklers 26', 20'

Total Spray Area 58935 f. Required Area 5854 s.f.

Distance from Water Well to Tank PWS and Spray Area _____

Distance from Spray Area to Property Line: 10'

Type of Pipe Used PVC License & Inspection Fee Paid? yes

Service Contract Rashaud Brown #1702

Installed By: Rashaud Brown #29989

Does construction meet the standards set forth in Chapter 285, of the Texas Administrative Code for ON-Site Sewerage Facilities? yes

Remarks All components working at time of inspection.

Date 3/13/24

AB/BS 37804

OSSF Inspector

Note: The County of Liberty accepts no responsibility for the operation of any sewer

This serves to notify all persons that the on-site sewage facility owned by the above has satisfied design, construction, and installation requirements of Liberty County and the T.C.E.Q. This On-Site Sewage Facility Permit is issued for the operation of the above identified OSSF.

N: 30.25094 W: -95.12736