



Ector County Health Department

221 N. Texas
Odessa, TX 79761
(432) 498-4141

On-Site Sewage Facility Permit OSSF PERMIT #: 12354

Owner: LeeRoy Ramirez & Rodrigo Cerecores

Location: 14050 Silver Fox Trail West, Odessa, TX
Lot 4 Westcliff Industrial Park

Installer: Armando Guterrez **Site Evaluation Date:** 07/25/2023

Site Evaluator (SE): Armando Gutierrez **Soil Classification:** 0.38

System Designer: Jorge L. Martinez **Gravel (measured by SE):** 37% %

Floodplain Status: Outside **Drinking Water Source:** Private Water Supply

Authorization to Construct: 08/25/2023

Final Inspection: 09/19/2023

Tank GPS : N 31.77126°
W -102.51593°

SOIL DESCRIPTION

0-1 ft: Class II (0.25 Gal/Day/sqFt)*
 1-5 ft: Layered Rock (unsuitable)
 0-1 ft: Class II (0.25 Gal/Day/sqFt)
 1-5 ft: Layered Rock (unsuitable)

Well GPS: N °
W °

Proposed Improvement: Office

Number of Bedrooms:

Number of Employees/Spaces: 30

Maximum Permitted Daily Flow: 150 gallons per day

Treatment Type: Septic

Primary Tank Volume: 1083 Gallons

Clarifier Tank Volume: Gallons

Pump Tank Volume: Gallons

Tank Manufacturer:

Disposal type: Soil Sub & LC Panels

Panel Length: 5.0 feet

Drainfield Length: 30 feet

Drainfield Width: 11 feet

Additional Requirements:

Kelby Upchurch,

Agency

09/19/2023

Date