

6,600+/- SF  
9,200+/- SF  
48,000+/- SF

2,670 SF | 26 OCC

1988?

extend sprinkler system  
into existing shipping &  
receiving area

S-2  
3,000 SF  
6 OCC.

F-2  
57,830 SF | 578 OCC  
SPRINKLERED

provide 1 hour rated  
walls (u.i. design U205)  
& 1 hour rated floor/  
ceiling assembly (u.i.  
design L501) & wood  
frame portion of office  
(see attached sheet for  
u.i. assemblies)

24'

32'

\*eliminate existing overhead  
door (typ.)

SPRINKLERED

PCA

F-1

23,250 SF | 233 OCC

36'

18'

36'

F-2

11,600 SF

116 OCC

\*MOVE PULL STATION FOR FIRE  
ALARM PULL STATION AND MOUNT  
@ 48" A.F.F. TO BOTTOM OF BOX

57'

sprinklered

SPRINKLERED

1968

F-1

135,975 SF | 1359 OCC

24'

32'

24'

extend sprinkler system  
into maintenance shop  
area & adjacent room

SPRINKLERED

1968

F-2

53,375 SF | 533 OCC

24'

\*protect telephone room  
w/ sprinkler head above

unleased

B

7,640

76 OCC

24'

SPRINKLERED

B

14,750 SF | 147 OCC

16'

PCA

B

16,310 SF

163 OCC

24'

2nd flr. unleased

use group square footage % of total

1 main floor plan - use groups

a1.1 scale: 1/32" = 1'-0"