



Ector County Health Department

221 N. Texas
Odessa, TX 79761
(432) 498-4141

On-Site Sewage Facility Permit OSSF PERMIT #: 12354

Owner: LeeRoy Ramirez & Rodrigo Cerecores
Location: 14050 Silver Fox Trail West, Odessa, TX
Lot 4 Westcliff Industrial Park
Installer: Armando Guterrez
Site Evaluator (SE): Armando Gutierrez
System Designer: Jorge L. Martinez
Floodplain Status: Outside
Authorization to Construct: 08/25/2023
Final Inspection: 09/19/2023
Site Evaluation Date: 07/25/2023
Soil Classification: 0.38
Gravel (measured by SE): 37% %
Drinking Water Source: Private Water Supply

Tank GPS : N 31.77126°
W -102.51593°

SOIL DESCRIPTION

Well GPS: N °
W °

0-1 ft: Class II (0.25 Gal/Day/sqFt)*
1-5 ft: Layered Rock (unsuitable)
0-1 ft: Class II (0.25 Gal/Day/sqFt)
1-5 ft: Layered Rock (unsuitable)

Proposed Improvement: Office
Number of Bedrooms:
Number of Employees/Spaces: 30
Maximum Permitted Daily Flow: 150 gallons per day
Treatment Type: Septic
Primary Tank Volume: 1083 Gallons
Clarifier Tank Volume: Gallons
Pump Tank Volume: Gallons
Tank Manufacturer:
Disposal type: Soil Sub & LC Panels
Panel Length: 5.0 feet
Drainfield Length: 30 feet
Drainfield Width: 11 feet

Additional Requirements:

Kelby Upchurch,

Agency

09/19/2023

Date