

## WATER WELL REPORT

Start Card No. W189156  
 Unique Well I.D. # ALC273  
 Water Right Permit No.

STATE OF WASHINGTON

179755

(1) OWNER: Name LAVINE GARY LYNDIA(01987) Address 8233 HWY 14 LYLE, WA 98635-

(2) LOCATION OF WELL: County KLIKITAT

(2a) STREET ADDRESS OF WELL (or nearest address) 9257 HWY 14 WISHRAM HGHTS, WISHRAM - SE 1/4 SE 1/4 Sec 7 T 2 N., R 15E WM

(3) PROPOSED USE: DOMESTIC

(10) WELL LOG

(4) TYPE OF WORK: Owner's Number of well 1  
 (If more than one)  
 NEW WELL Method: ROTARY

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change in formation.

(5) DIMENSIONS: Diameter of well 8 inches  
 Drilled 675 ft. Depth of completed well 675 ft.

(6) CONSTRUCTION DETAILS:  
 Casing installed: 8 " Dia. from +1 ft. to 26 ft.  
 WELDED " Dia. from ft. to ft.  
 " Dia. from ft. to ft.

Perforations: NO

Type of perforator used

SIZE of perforations in. by in.

perforations from ft. to ft.

perforations from ft. to ft.

perforations from ft. to ft.

Screens: NO

Manufacturer's Name

Type

Model No.

Diam. slot size from ft. to ft.

Diam. slot size from ft. to ft.

Gravel packed: NO

Size of gravel

Gravel placed from ft. to ft.

Surface seal: YES

To what depth? 20 ft.

Material used in seal CEMENT &amp; BENTO.

Did any strata contain unusable water? NO

Type of water? Depth of strata ft.

Method of sealing strata off

(7) PUMP: Manufacturer's Name NA

Type

H.P.

(8) WATER LEVELS:

Land-surface elevation

above mean sea level ft.

Static level 520 ft. below top of well Date 08/11/05

Artesian Pressure lbs. per square inch Date

Artesian water controlled by

Work started 08/04/05

Completed 08/11/05

(9) WELL TESTS: Drawdown is amount water level is lowered below static level.

Was a pump test made? NO If yes, by whom?

Yield: gal./min with ft. drawdown after hrs.

Recovery data

Time Water Level Time Water Level Time Water Level

Date of test / /

Bailer test gal./min. ft. drawdown after hrs.

Air test 60 gal./min. w/ stem set at 665 ft. for 1 hrs.

Artesian flow g.p.m. Date

Temperature of water Was a chemical analysis made? NO

WELL CONSTRUCTOR CERTIFICATION:

I constructed and/or accept responsibility for construction of this well, and its compliance with all Washington well construction standards. Materials used and the information reported above are true to my best knowledge and belief.

NAME M-K DRILLING CO.

(Person, firm, or corporation) (Type or print)

ADDRESS BOX 470 DALLSPORT, WA

[SIGNED] *Harold Moore JR* License No. 0833(2740)2560

Contractor's

Registration No. MKDRIC134PE

Date 08/23/05

