

STATE OF TEXAS WELL REPORT for Tracking #620720

Owner:	JT Sivils	Owner Well #:	No Data
Address:	5165 Loneman Mountain Rd Wimberley, TX 78676	Grid #:	57-64-6
Well Location:	5165 Loneman Mountain Rd Wimberley, TX 78676	Latitude:	30° 03' 06.7" N
Well County:	Hays	Longitude:	098° 01' 52" W
		Elevation:	1079 ft. above sea level
Type of Work:	New Well	Proposed Use:	Domestic

Drilling Start Date: 9/12/2022 Drilling End Date: 9/12/2022

	Diameter (in.)	Top Depth (ft.)	Bottom Depth (ft.)
Borehole:	14.75	0	40
	8.75	40	650

Drilling Method: Air Rotary

Borehole Completion: Straight Wall

	Top Depth (ft.)	Bottom Depth (ft.)	Description (number of sacks & material)
Annular Seal Data:	0	470	Cement 132 Bags/Sacks

Seal Method: Pressure

Sealed By: Driller

Distance to Property Line (ft.): 50

Distance to Septic Field or other
concentrated contamination (ft.): N/A

Distance to Septic Tank (ft.): N/A

Method of Verification: Well drilled first

Surface Completion: Surface Sleeve Installed

Surface Completion by Driller

Water Level: No Data

Packers: Burlap/Rubber at 460 ft.
Burlap/Rubber at 465 ft.
Burlap/Rubber at 470 ft.

Type of Pump: Submersible

Well Tests: Jetted Yield: 30 GPM

Water Quality:

Strata Depth (ft.)	Water Type
550 - 650	Middle Trinity

Chemical Analysis Made: **No**

Did the driller knowingly penetrate any strata which
contained injurious constituents?: **No**

Certification Data: The driller certified that the driller drilled this well (or the well was drilled under the driller's direct supervision) and that each and all of the statements herein are true and correct. The driller understood that failure to complete the required items will result in the report(s) being returned for completion and resubmittal.

Company Information: **Centex Pump & Supply, Inc.**
2520 Hwy. 290 West
Dripping Springs, TX 78620

Driller Name: **Martin Lingle**

License Number: **54813**

Comments: **No Data**

Lithology:
DESCRIPTION & COLOR OF FORMATION MATERIAL

Top (ft.)	Bottom (ft.)	Description
0	4	Top Soil
4	24	Caliche
24	100	Brown
100	150	Gray
150	300	Gray & Tan
300	500	Tan & White
500	650	Tan Brown Fractured

Casing:
BLANK PIPE & WELL SCREEN DATA

Dia (in.)	Type	Material	Sch./Gage	Top (ft.)	Bottom (ft.)
10	Surface	New Plastic (PVC)	40	0	40
4.5	Blank	New Plastic (PVC)	SDR17	2	550
4.5	Perforated or Slotted	New Plastic (PVC)	SDR17	550	650

IMPORTANT NOTICE FOR PERSONS HAVING WELLS DRILLED CONCERNING CONFIDENTIALITY

TEX. OCC. CODE Title 12, Chapter 1901.251, authorizes the owner (owner or the person for whom the well was drilled) to keep information in Well Reports confidential. The Department shall hold the contents of the well log confidential and not a matter of public record if it receives, by certified mail, a written request to do so from the owner.

Please include the report's Tracking Number on your written request.

Texas Department of Licensing and Regulation
P.O. Box 12157
Austin, TX 78711
(512) 334-5540