

STATE OF TEXAS WELL REPORT for Tracking #513314

Owner:	DRIPPING SPRINGS WATER SUPPLY CORP.	Owner Well #:	No Data
Address:	101 HAYS ST., SUITE 406 DRIPPING SPRINGS, TX 78620	Grid #:	57-56-8
Well Location:	F. M. 150 DRIPPING SPRINGS, TX 78620	Latitude:	30° 09' 15.12" N
Well County:	Hays	Longitude:	098° 04' 05.16" W
		Elevation:	No Data

Type of Work: TEST WELL	Proposed Use: Test Well
--------------------------------	--------------------------------

Drilling Start Date: **4/17/2019** Drilling End Date: **4/17/2019**

	Diameter (in.)	Top Depth (ft.)	Bottom Depth (ft.)
Borehole:	9.25	0	18
	6.75	18	450

Drilling Method: **Air Rotary**

Borehole Completion: **Straight Wall**

	Top Depth (ft.)	Bottom Depth (ft.)	Description (number of sacks & material)
Annular Seal Data:	0	18	HOLE PLUG 4 Bags/Sacks

Seal Method: **Not Applicable**

Sealed By: **Driller**

Distance to Property Line (ft.): **2000+**

Distance to Septic Field or other concentrated contamination (ft.): **N/A**

Distance to Septic Tank (ft.): **N/A**

Method of Verification: **OWNER**

Surface Completion: **TEST WELL**

Surface Completion NOT by Driller

Water Level: **105 ft. below land surface on 2019-04-17** Measurement Method: **Electric Line**

Packers: **Burlap at 18 ft.**

Type of Pump: **No Data**

Well Tests: **Jetted** **Yield: 200+ GPM**

Water Quality:	Strata Depth (ft.)	Water Type
	260 - 440	COW CREEK

Chemical Analysis Made: **Yes**

Did the driller knowingly penetrate any strata which contained injurious constituents?: **No**

Certification Data: The driller certified that the driller drilled this well (or the well was drilled under the driller's direct supervision) and that each and all of the statements herein are true and correct. The driller understood that failure to complete the required items will result in the report(s) being returned for completion and resubmittal.

Company Information: **Centex Pump & Supply, Inc.**
2520 Hwy. 290 West
Dripping Springs, TX 78620

Driller Name: **MARTIN DALE LINGLE** License Number: **54813**

Comments: **There was a chemical analysis made by the Environmental Laboratory Services**

Lithology:
 DESCRIPTION & COLOR OF FORMATION MATERIAL

Casing:
 BLANK PIPE & WELL SCREEN DATA

Top (ft.)	Bottom (ft.)	Description
0	3	TOP SOIL
3	12	BROWN LIMESTONE
12	15	BLUE LIMESTONE
15	130	TAN/GRAY LIMESTONE
130	160	GRAY LIMESTONE W/CLAY
160	170	BROWN LIMESTONE
170	200	TAN LIMESTONE
200	210	GRAY LIMESTONE
210	220	TAN/GRAY LIMESTONE
220	230	TAN LIMESTONE
230	240	GRAY LIMESTONE
240	250	TAN/GRAY LIMESTONE
250	260	TAN LIMESTONE
260	270	BROWN LIMESTONE
270	290	TAN LIMESTONE
290	310	TAN LIMESTONE
310	355	TAN/GRAY LIMESTONE
355	430	BROWN LIMESTONE

Dia (in.)	Type	Material	Sch./Gage	Top (ft.)	Bottom (ft.)
8	Blank	New Plastic (PVC)	SCH. 40	2	18

430	440	GRAY LIMESTONE
440	450	GRAY CLAY

IMPORTANT NOTICE FOR PERSONS HAVING WELLS DRILLED CONCERNING CONFIDENTIALITY

TEX. OCC. CODE Title 12, Chapter 1901.251, authorizes the owner (owner or the person for whom the well was drilled) to keep information in Well Reports confidential. The Department shall hold the contents of the well log confidential and not a matter of public record if it receives, by certified mail, a written request to do so from the owner.

Please include the report's Tracking Number on your written request.

**Texas Department of Licensing and Regulation
P.O. Box 12157
Austin, TX 78711
(512) 334-5540**