



SECOND FLOOR PLAN

- NOTE: 1. UNLESS OTHERWISE NOTED, ALL NEW INTERIOR WALLS ARE 3/8" THICK. - METAL STUDS AT 24" O.C. - w/ SOUND ATTENUATION BLANKETS - EXTEND WALLS ABOVE RATED CLF AS REQ'D.  
 2. SHADED AREAS INDICATE EXISTING CONSTRUCTION TO REMAIN (TYP.).  
 3. FIRE RETARDANT TREATED WOOD BLOCKING TO BE INSTALLED IN METAL STUD WALLS AT INTERVALS APPROPRIATE FOR HANGING OF MARKER BOARDS, TACK BOARDS, ETC. (ONLY IN WALLS INDICATED).  
 4. CONTRACTOR TO VERIFY EXISTING FLOOR JOIST CONDITIONS. TRUSS IS TO BE FILLED. CONSULT W/ ARCH. OFFER. EXISTING CONDITIONS ARE BASED - PRIOR TO PROCEEDING W/ WORK.  
 5. PATCH ROOF AS REQ'D. PROVIDE A WATERPROOF SEAL AT NEW MECHANICAL EQUIPMENT CURBS. (PROVIDE FLASHING AS REQ. WHERE ELEVATOR SHAFT EXTENDS THROUGH EXIST. ROOF).  
 6. FIRE STOP IN LOCATIONS SPECIFIED IN BOGA 921.6.  
 7. PROVIDE ASPHALT SHINGLE ROOF OVER 30-LB. ROOFING FELT ON WOOD FRAME ROOF OVER ELEVATOR HOISTWAY.

SCALE: 3/16" = 1'-0"

DATE: 1-12-93

REVISIONS:

1	3-24-93
2	3-31-93

SHEET:  
**A5**