



NOTES:

- TEMPERATURE & PRESSURE RELIEF VALVE WATTS NO. 240-1/8" (1,975,000 B.T.U. RATING).
- PRESSURE RELIEF VALVE WATTS NO. 30'-3/4".
- VACUUM RELIEF VALVE WATTS NO. 36'-3/4".
- H.W. STORAGE TANK & GENERATOR MATERIALS & CONSTRUCTION SHALL BE IN ACCORDANCE WITH A.S.M.E. & SHALL BE STAMPED ACCORDINGLY. H.W. STORAGE TANK SIZE - 4'0" X 8'0" L.O.S. 500 GALLONS. H.W. STORAGE TANK SHELL THICKNESS - 5/16". H.W. STORAGE TANK HEAD THICKNESS - 13/32". H.W. GENERATOR COIL SIZE - 25'0" FT. X 500 G.P.H.

GENERAL NOTES:

- KEEP ALL PIPING CLOSE TO UNDERSIDE OF ROOF FLOOR SLABS, COORDINATE WITH OTHER TRADES & CHECK ROOM HEIGHTS ON ARCHITECT'S FINISH SCHEDULE.
- EXTEND PIPE SLEEVES 1" ABOVE FINISH FLOOR.

GENERAL NOTES:

SEAL

SEAL

SCALE	DATE	CHURCH OF ST. FRANCIS CENTER OF ASSISI MEDFORD, MASSACHUSETTS MONSIGNOR FOLEY, PASTOR	PROJECT NO. 642
DR. J. A. M.			
REVISIONS:		PLUMBING - FIRST FLOOR PLAN	1-2
EDWARD J. TEDESCO ASSOCIATES ARCHITECTS A.I.A. 48 MOUNT VERNON STREET WINCHESTER, MASSACHUSETTS		JOSEPH A. MONTANO ASSOCIATES MECHANICAL ENGINEERS FRAMINGHAM, MASSACHUSETTS	