



Ector County Health Department

221 N. Texas
Odessa, TX 79761
(432) 498-4141

On-Site Sewage Facility Permit OSSF PERMIT #: 12320

Owner: John Loepky
Location: 14661 IH 20 W., Odessa, TX
Lot 5 Block 1 Basin Industrial South
Installer: Franz Bergen
Site Evaluator (SE): Franz Bergen
System Designer: Jorge L. Martinez
Floodplain Status: Outside
Authorization to Construct: 08/02/2023
Final Inspection: 10/10/2023
Site Evaluation Date: 06/03/2023
Soil Classification: 0.38
Gravel (measured by SE): 30% %
Drinking Water Source: Private Water Supply

Tank GPS : N 31.76337°
W -102.52884°

Well GPS: N °
W °

SOIL DESCRIPTION

0-3 ft: Class II (0.25 Gal/Day/sqFt)*
3-5 ft: Layered Rock (unsuitable)
0-2 ft: Class II (0.25 Gal/Day/sqFt)
2-5 ft: Layered Rock (unsuitable)

Proposed Improvement: Office
Number of Bedrooms:
Number of Employees/Spaces: 20
Maximum Permitted Daily Flow: 200 gallons per day
Treatment Type: Septic
Primary Tank Volume: 1200 Gallons
Clarifier Tank Volume: Gallons
Pump Tank Volume: Gallons
Tank Manufacturer:
Disposal type: Soil Sub & LC Panels
Panel Length: 5.0 feet
Drainfield Length: 40 feet
Drainfield Width: 11 feet

Additional Requirements:

Kelby Upchurch,

Agency

10/10/2023

Date



Ector County Health Department

221 N. Texas Ave
Odessa, TX 79761
(432) 498-4141

Notice of Approval & License to Operate an On-Site Sewage Facility PERMIT #: 12320

Location: 14661 IH 20 W., Odessa, TX 79763-
Lot 5 Block 1 Basin Industrial South
Owner: John Loepky
Mailing address: 430 US Hwy 180 W., Seminole, Tx 79360-

Proposed Improvement:	Office	
Type of OSSF:	Treatment Type:	Septic
	Disposal Type:	Soil Sub & LC Panels
	Maximum Flow:	200 Gallons per Day
	Primary Tank Size	1200 Gallons
	Clarifier Tank Size	Gallons
	Pump Tank Size	Gallons
	Drainfield:	24 - 5.0 Feet Long Panels
	Drainfield Dimensions:	40 x 11 feet

This serves to notify all persons that the on-site sewage facility owned by the above has been approved, satisfying design, construction, and installation requirements of the Texas Commission on Environmental Quality (TCEQ).

This On-Site Sewage Facility (OSSF) Permit and License to Operate is issued for the operation of the above-identified on-site sewage facility. State standards do not guarantee that an OSSF will perform satisfactorily under all conditions. It is the responsibility of the owner to maintain and operate the facility in a satisfactory manner.

The issuance of this license to operate an OSSF shall only indicate that the facility meets the minimum requirements for issuance of this license.

Any modifications to the size of the business or alteration of the OSSF requires a new permit. Water supply lines are required to be placed at least 10 feet from sewer lines and any part of the OSSF. Water lines shall not cross sewer lines unless they have been engineered to meet TAC Chapter 290. Failure to maintain these separation distances will result in revocation of your Permit and License to Operate.

Additional Requirements:

Kelby Upchurch,

Agency

October 10, 2023

Date