

36409

125 gal
312 # 10:30

LINCOLN COUNTY HEALTH DEPARTMENT

302 NORTH ACADEMY STREET • LINCOLNTON, N.C. 28092 • (704) 736-8426

Application Type: EH IMPROVEMENT APPLICATION

Date: 4/27/00

Permit #: 00-90000429 PIN: 3653 -01 -03 -7003 Parcel ID: 72537

Owner: INGLE, DARREN E & KIMBERLY (704) 732-3830

PO BOX 494 LINCOLNTON NC 28093

Applicant: INGLE, WILLIAM EDWARD (704) 732-3830

P O BOX 1013 LINCOLNTON NC 28093

Directions to property: JOSHUA COURT

HWY 27 E, TURN L ON JOSHUA COURT BETWEEN


LENNOX & MARTIN'S AUTO, 2ND LOT ON L.

UPHOLSTERY SHOP, 5 EMP, 8750 SQ FT.

Residence: N

Nbr of Bedrooms: _____

Water Supply: PUBLIC

☒ IMPROVEMENT PERMIT☐ REPAIR☐ LOT DENIED2 lines
3x52
12" stoneCharge
2.11-200 BWAMax Trench
Depth
24"system
will be
installed
on side
10-19-2000AUTHORIZATION TO CONSTRUCT ☒TYPE OF SYSTEM Shallow Gravity 24" Trench DepthTANK SIZE 1000ABSORPTION AREA 312 #TRENCH WIDTH & LENGTH 3x52NUMBER OF TRENCHES 2TRENCH SPACING 9 OCGRAVEL DEPTH 12"DISTANCE TO WATER SUPPLY Public FT.DESIGN FLOW 125 gpm LTAR 4CONDITIONS Shy off all property lines. Installlines on contour. Provided tank, filter & markerMax trench depth 24" due to septicHEALTH DEPT. REP. [Signature]☒ FINAL COMPLETION☐ OP☐ RC2 lines
3x50
24" stone

140' (Road) Joshua Ct

TANK MANUFACTURER GMTANK SIZE 1000 galABSORPTION AREA 300 #TRENCH WIDTH & LENGTH 3x50NUMBER OF TRENCHES 2GRAVEL DEPTH 24"DISTANCE TO WATER SUPPLY Public FT.INSTALLER Gary MillerCONDITIONS System is 10ft off all property linesLines installed on contour. Tank providedw/ filter & markerHEALTH DEPT. REP. [Signature]