



PER: _____
CHIEF BUILDING OFFICIAL



Where supply or return air ducts are located in an unheated space, they shall be insulated to provide a thermal resistance of not less than RSI 2.1 (R 12)

1. ALL S/A DIFFUSERS 4"x10" UNLESS NOTED OTHERWISE ON LAYOUT. ALL S/A DIFFUSERS TO BE 1" UNLESS NOTED OTHERWISE ON LAYOUT. UNDERCUT DOORS 3" min. FOR R/A
2. ALL RETURN AIR PARTITIONS TO BE 6"
3. STOP DUCT 3" IF COLD CELLAR DOOR IS INSTALLED
4. DESIGNER MUST BE CONSULTED PRIOR TO INSTALLATION OF KITCHEN EXHAUST FAN EXCEEDING 200 CFM.
5. INSTALLATION TO COMPLY WITH THE LATEST ONTARIO BUILDING CODE. ALL SUPPLY BRANCH OUTLETS SHALL BE EQUIPPED WITH A MANUAL BALANCE DAMPER. DAMPER MARK WHICH PASSES THROUGH THE GARAGE OR UNHEATED SPACES SHALL BE ADEQUATELY INSULATED AND BE GAS-PROOFED.

ct No.
14973

2