

JOHNSTON COUNTY HEALTH CENTER - DIVISION OF ENVIRONMENTAL HEALTH
205 South Second Street - Smithfield, North Carolina 27577
Telephone 934-7606

IMPROVEMENT PERMIT - ALTERNATIVE SEPTIC TANK SYSTEM

Permit No. 7729

Date Issued 4-18-86

NAME ~~Keith~~ Shirley's Truck Stop FACILITY TYPE Restaurant

OWNER Keith Bond ADDRESS Selma

LOCATION Hwy 70 E - on Rt 1 Wayne Co line

REPORT NUMBER _____ LOT AREA _____

SOIL CLASSIFICATION Snit

NEW CONSTRUCTION _____ REPAIR yes

DESIGN DAILY SEWAGE FLOW _____

SEPTIC TANK SIZE Existing

PUMP TANK SIZE ~~1000~~ 1200 gal. GREASE TRAP SIZE existing

PUMP(S) SIZE 1/2 Hp

DRAINFIELD TYPE conventional SQUARE FEET 1800

NUMBER LINES 6 LENGTH 100


WIDTH 36" DEPTH 24-30"

WATER SUPPLY Existing DEPTH _____

DESIGN/LAYOUT BY Sullivan PERMIT ISSUED BY Sullivan

System shall be installed as shown in sketch. This permit is good for 12 months from date of issue.

- ① Subsail area for Sewage lines
- ② plant cover grass over lines
- ③ install boundary to protect lines



WJS
4-23-86