Waste Water Demand Estimate

Project: Buena Vista Vineyard

Project Address: 3925 Buena Vista Dr, Paso Robles, CA 93446

APN: 025-390-011 & 025-390-038

Date: 03/12/2024



DOMESTIC DEMANDS

	Quantity	Туре	Flow Rate	Facility Demand (GPD)
1. HOTEL	155	Unit ¹	60	9,300
2. WINE TASTING	45	Guest ²	5	225
3a. RESTAURANT (within hotel)	1	Unit ³	1495	1,495
3b. RESTAURANT (separate)	1	Unit ³	1495	1,495
4. MEDICAL SPA COTTAGES	7	Bed ⁴	250	1,750
5. WEDDING PAVILION	200	Guest ²	5	1,000
6.1. MAINTENANCE BUILDING - EMPLOYEE	4	Employee ⁵	20	80
6.2. HOTEL - EMPLOYEE	10	Employee ⁵	20	200
6.3. WINE TASTING - EMPLOYEE	6	Employee ⁵	20	120
6.4. RESTAURANT - EMPLOYEE	20	Employee ⁵	20	400
6.5. MEDICAL SPA - EMPLOYEE	6	Employee ⁵	20	120
6.6. WEDDING PAVILION - EMPLOYEE	10	Employee ⁵	20	200
6.7. GUEST ENTRY LOBBY AND VALEY - EMPLOYEE	2	Employee ⁵	20	40
7. LAUNDRY	7.5	Cycle ⁶	50	375
8. COTTAGES	30	Unit ⁷	60	1,800
9. TENTS	8	Unit ⁸	15	120
10. CONFERENCE MEETING CENTER	150	Guest ²	5	750
	<u> </u>		Subtotal	19,470

Notes:

CPC Table H 201.1(4) was used to determine gpd for each use:

- 1. Hotel no kitchen CPC Table H 201.1(4) Estimated @ 60 gpd/bed
- 2. Event center assessed with code as dance hall CPC Table H 201.1(4) Estimated @ 5 gpd/person
- 3. Restaurants: [CPC Table H 201.1(4) Estimated patrons @ 7 gpd/patron + Kitchen/Dining/Garbage Demand @ 6 gpd/meal]; 75 seats with dining turnover expected at 115 patrons total, 115 meals.
- 4. Medical use assessed with CPC Table 201.1(4) as like kind with Hospitals @ 250 gpd/bed.
- 5. Employee CPC Table H 201.1(4) Estimated @ 20 gpd/employee
- 6. Laundry Facilities CPC Table H 201.1(4) Estimated @ 50 gpd/cycle. Assumes 1/4 of rooms to wash per day with 2 rooms per machine cycle.
- 7. Motel with kitchen CPC Table H 201.1(4) Estimated @ 60 gpd/unit
- 8. Camps (day) with no meals served CPC Table H201.1(4) Estimated @ 15gpd/person