OSE/I	PE Report For:			
Construction Repair Permit	Voluntary Upgrade Certification Subdivision Permit Letter Approval			
Property Location:				
911 Address:	City:			
Lot 12 Section				
26F 1 12	Health Dept ID #			
	Longitude			
Applicant or Client Mailing Address: Name: Tolers Bridge Investments				
Street: 4200 Evergreen Lane Suite 323				
City: Annandale	State VAZip Code 22003			
Prepared by: OSE Name Clifton D. Overstreet Address 1684 Magnolia Dr.	License # 1104			
B If	VA 24522			
City Bedford	State VA Zip Code 24523			
PE Name	License #			
Address				
City	State Zip Code			
Date of Report 7-17-2018 Date of Revision #1				
OSE/PE Job #	Date of Revision #2			
Contents/Index of this report (e.g., Site Evaluation Summan. Cover Sheet	nary, Soil Profile Descriptions, Site Sketch, Abbreviated Design, etc.)			
Soil Information Summary	5. Site Sketch			
3. Abbreviated Design Information	6. Well Addendum			
4. Soil Profile	A distributed as			
Certification Statement I hereby certify that the evaluations and/or designs contained herein were conducted in accordance with the applicable provisions of the Sewage Handling and Disposal Regulations (12 VAC5-610), the Private Well Regulations (13 VAC5-630), the Regulations for Alternative Onsite Sewage Systems (12 VAC5-613) and all other applicable laws, regulations and policies implemented by the Virginia Department of Health. I further certify that I currently possess any professional license required by the laws and regulations of the Commonwealth that have been duly issued by the applicable agency charged with licensure to perform the Worklood ained herein. The potential for both conventional and alternative onsite sewage systems has been discussed with the owner/applicant. The work attached to this cover page has been conducted under an exemption to the practice of engineering, specifically				
I recommend that a (select one): construction permit certification letter subdivision approval be (select one) Issued repair permit voluntary upgrade				

1684 Magnolia Dr. Bedford, VA 24523 PHONE: (804) 467-4480 (540) 815-2954 Doug.Overstreet@gmail.com A.O.S.E. #1104

DATE: July 17, 2018

SUBMITTED TO: Bedford County Health Department

APPLICANT: Tolers Bridge Investments

4200 Evergreen Lane Suite 323

Annadale, VA 22003

LOCATION: Lot 12; Sportsman's Point, 15.152 acres; Bedford County; Virginia

PROPOSED USE: New Single Family Residence

3 Bedroom (450 gallons/day), Termite treated, No Basement

WATER SUPPLY: New Private Class III C Well, Deep Drilled

PROPOSED INSTALLATION: New Type I, In-Ground Septic Tank Effluent Drainfield System (Conventional Gravity)

SOIL INFORMATION SUMMARY:

Parent Material: Soils are residual, weathered rocks of the Piedmont Physiographic Province.

Position in landscape satisfactory: Yes X No .

Description of landscape: Upland sideslope, linear-linear topo, Wooded sideslope.

Slope: 16% Depth to Cr or rock: 44"

Depth to impervious strata ($\underline{N/A}$): Max. $\underline{Min.}$ None \underline{X} .

Depth to Redox mottles: N/A in. Depth to Chroma 2 mottles: N/A in.

Free water present: Yes ___ No X Range N/A in.

Soil percolation rate: 60 min/in. (Estimated). Texture Group: III.

Site Evaluated By: Doug Overstreet/ AOSE #1104 Date of Evaluation: June 11, 2018

WATER SUPPLY CONSTRUCTION SPECIFICATIONS:

Proposed Water Supply: <u>Class IIIC</u> Cased: <u>20'+</u> Grouted: 20'+

This is not a Drainfield Construction Permit. This report is to certify that an area exists for the permitting of a drainfield and well. This report is valid only if presented to the local VDH office for their approval. For this approval the report must be accompanied by an application, fee and stamped plat showing the survey located drainfield area. Once approved this Letter of Certification does not expire and is transferable. When the permit is needed the local VDH or an AOSE must return to the property to complete the design \The squal type and design of the drainfield and well to be constructed will be determined at that time, based on site conditions and the regulations current during that visit. If the proposed drainfield area must be cleared before the parmy has been issued, follow the provided clearing instructions

Health Department ID. #

Map Reference #: 265-1-12

1684 Magnolia Dr. Bedford, VA 24523
PHONE: (804) 467-4480 (540) 815-2954 Doug.Overstreet@gmail.com
A.O.S.E. #1104

LOCATION: Lot 12; Sportsman's Point, 15.152 acres; Bedford County; Virginia

ABBREVIATED DESIGN INFORMATION:

Proposed Primary Drainfield: Type I, In-Ground Septic Tank Effluent Drainfield System (Conventional Gravity)

Soil percolation rate: 60 min/in. (Estimated). Texture Group: III .

Separation distance required: <u>18</u> in. Limiting depth (<u>Rock</u>): <u>44</u> in.

Depth from ground surface to bottom of trench: 26 in.

Square ft. required per bedroom: 452.

Total square ft. required for drainfield: 3 bedroom 1356.

Design layout for primary drainfield:

 $\underline{5}$ lines x $\underline{100}$ ft. in length x $\underline{3}$ ft. wide = $\underline{1500}$ sq. ft.

Center-to-Center spacing proposed adjusting for slope: 10 ft.

Area needed for design: 43' x 100' (4300 sq. ft.)

Area documented: 80' x 100' (8000 sq. ft.)
Depth of aggregate: 13" of ½" to 1 ½" of clean stone

Proposed Reserve Drainfield: Type II, In-Ground Advanced Pretreatment Drainfield System

(TL-3 Treatment to LPD Trench) Soil percolation rate: 60 min/in. (Estimated). Percent Reserve: 100%.

Minimum installation depth required by system and/or slope: 0 in.

Separation distance required: 12 in. Limiting depth (rock_): 44 in.

Depth from ground surface to bottom of trench: 26 in.

Gallons per day: 450

Gallons per square ft.: __89_.

Total square ft. required for drainfield: 506.

Possible design layout for primary drainfield: trenches

3 bedroom: $\underline{2}$ lines $x \underline{100}$ ft. in length $x \underline{3}$ ft. wide = $\underline{600}$ sq. ft

Area needed for design: 13'+x 100'+(1300 sg. ft.)

Area documented: 80' x 100' (8000 sq. ft.)





1684 Magnolia Dr. Bedford, VA 24523
PHONE: (804) 467-4480 (540) 815-2954 Doug.Overstreet@gmail.com
A.O.S.E. #1104

LOCATION: Lot 12; Sportsman's Point, 15.152 acres; Bedford County; Virginia

SOIL PROFILE:

HOLE# NAME	HORIZO	N DEPTH INCHES	DESCRIPTION OF SOIL CHARACTERISTICS	TEXTURE GROUP
#1 CDO	A Bt1	0-4 4-30	7.5YR 5/4 brown; loam 2.5YR 5/6 red; friable; heavy clay loam	III
#2	BC A	30-60+ 0-4	2.5YR red with 5YR 5/6 yellowish red; friable; light clay loam to loam 7.5YR 5/4 brown; loam	III/II II
CDO	Bt1 BC	4-30 30-44 44	2.5YR 5/6 red; friable; heavy clay loam 2.5YR red with 5YR 5/6 yellowish red; friable; light clay loam Hole terminated on rock	III
#3 CDO	A Bt1 BC	0-4 4-30 30-48+	7.5YR 5/4 brown; loam 2.5YR 5/6 red; friable; heavy clay loam 2.5YR red with 5YR 5/6 yellowish red; friable; light clay loam to loam	II III III/II




1684 Magnolia Dr. Bedford, VA 24523

PHONE: (804) 467-4480 (540) 815-2954 Doug.Overstreet@gmail.com A.O.S.E. #1104

LOCATION: Lot 12; Sportsman's Point, 15.152 acres; Bedford County; Virginia

SITE SKETCH:

Included on this site sketch are existing and/or proposed property lines, primary and reserve drainfield area, proposed building location, driveway, well and soil evaluation borings with an accuracy of +- three feet. As well as any observed existing structures, wells, or drainfields within 150'+ of the proposed area. All natural geographic features such as drainways, springs, gulleys, etc. that would impact the site evaluation are also included. Any feature not shown on the site sketch were either not observed, did not pertain to this evaluation, or do not exist.



Page Got 6

Addendum to AOSE/PE Certification Statement For Private Well Construction Permit

Instructions: Please check one box in 1-3 below. Statement templates for item #2 and #3 are on the following pages.

The	prop	posed well site shown herein,
X	1.	Is located a minimum of 50 feet from all property lines.
	2.	Is located within 50 feet of the adjacent property line(s) but I have determined that the adjacent property is <u>not</u> used for an agricultural operation.
		 i. Written affirmation from the adjacent property owner(s) that their property is <u>not</u> used for an agricultural operation. ii. Other confirmation that land use is <u>not</u> an agricultural operation, please describe:
	3.	Is located within 50 feet of an adjacent property line where the property is used for an agricultural operation. For confirmation, I have attached the appropriate documentation pursuant to § 32.1-176.5:2 of the <i>Code of Virginia</i> . (check one below)
		i. Written permission from the adjacent property owner(s) for the well construction.
		ii. I certify that no other site on the property complies with the Board's Regulations for the construction of a private well.

