



UPPER FIRE AREA 2 - BUSINESS OCCUPANCY - 1088 SQ. FT.
2 EXITS REQUIRED - 3 EXITS PROVIDED

STAIRS 1 IS NOT PART OF ANY EGRESS SCHEME. PARTITION WITH WINDOWS IS A SMOKE BARRIER AND SEPARATES FIRE AREA 2 INTO TWO SMOKE COMPARTMENTS - LOWER & UPPER LEVELS.

108' TO EXIT 5
44' TO EXIT 6

63' TO EXIT 4
117' TO EXIT 5

GENERAL NOTES:

SCALE: 1/8" = 1'-0"

- GENERAL NOTES:**
1. COMMON PATH OF TRAVEL IS 100' WITH SPRINKLERS.
 2. TOTAL EXIT ACCESS PATH OF TRAVEL IS 300' WITH SPRINKLERS.
 3. 3 FIRE EXTINGUISHERS (2A:10:B:C) ARE PROVIDED ON EACH LEVEL (MAX. 1500 S.F. PER UNIT OF A).

CONSTRUCTION
DOCUMENTS
PERMIT SET
ISSUED 10.10.2003

SCALE: 1/8" = 1'-0"

- NOTES PER LSC CHAPTER 20:
1. DOORS IN 1-HR PARTITIONS ARE PERMITTED TO BE 1 3/4" THICK SOLID CORE.
 2. WIRE GLASS WINDOWS NOT EXCEEDING 1296 SQ. IN. PER PANEL ARE PERMITTED IN 1-HR FIRE PARTITIONS. WIRE GLASS PANELS ARE SET IN HOLLOW METAL FRAMES.
 3. SPRINKLERS ARE NOT REQUIRED BUT WILL BE PROVIDED THROUGHOUT PER NFPA 13.
 4. REFER TO CODE INFORMATION ON TITLE SHEET FOR EGRESS CAPACITIES.

ALPINE CLINIC

Franconia, New Hampshire

COPYRIGHT 2008
SAMYN-D'ELIA Architects

LIFE SAFETY PLANS

PROJECT NO: 0811	PROJECT DATE: -
PLOT DATE: 10/10/2008	
FILE NAME: 0811 Plans	

REVISIONS

SHEET NO.

LSO