

ON-SITE SEWAGE CONSTRUCTION PERMIT

TANK PLACEMENT

2011-220

SIR# 2002-00393

SEP# 2011-00231

APPLICANT INFORMATION (Property Title Owner)*

NAME: **RCRS PROPERTIES LLC**
CURRENT
ADDRESS: **4701 SW ADMIRAL WAY #12**
CITY: **SEATTLE, WA. 98116**

PHONE:
Denial or approval of an On-Site Sewage Disposal Permit may be
appealed to the Health Officer within 15 days of the decision date.

This construction permit expires 3 years from date of issuance.
Repair Permits are valid for 6 months only.
Any change in building or sewage disposal plans or location invalidates
Health Division and Licensed Designer.

JERRY L. JACOBS

I hereby acknowledge that I have read this application and state that the
information supplied is correct. I agree to comply with all County and
State laws regulating activities covered by this permit.
No refund available after plan review completed.

*Purchaser may also be listed here:

APPLICANT SIGNATURE DATE
RCRS PROPERTIES **12/13/2011**
By Designer:
Name: Jerry L. Jacobs

Address: On-Site Services
PO Box 1688
Port Angeles WA 98362
360-452-3905

PROJECT INFORMATION

DIRECTIONS TO PROJECT SITE (from Courthouse).

East on hwy 101, south Deer park Road, East into
Stillwood Estates, North on Birdsong Lane

PROJECT ADDRESS: **202 Birdsong Lane**

LOT SIZE: **5.0 (A)/SF** ZONING #BEDROOMS

WATER SYSTEM: **PUD**

PROJECT DESCRIPTION: **COMMERICAL ADULT CARE**

TANK PLACEMENT ONLY

PLOT PLAN
NORTH

Draw a scaled or dimensioned plot plan of
the proposed site. Include all applicable
items listed in instructions.

SCALE: (See attached Drawing)

Critical Areas as shown on Map
(CRITICAL AQUIFER RECHARGE)

Soils:



Designer Signature <u>Janine M. Reed</u> 12-21-11		
Environmental Health Signature		
Approved	Denied	Date
Expiration Date <u>12-21-14</u>		
Installer <u>C & J Excavating</u>		
Signature <u>Janine M. Reed</u> 6/04/13		
FINALED BY		
DATE		
☐ INSPECTED ☒ AS BUILT		

SYSTEM TYPE: **AP COMMERCIAL**
COMMUNITY
SYSTEM NAME: **N/A**
NUMBER OF
CONNECTIONS: **N/A**
SYST USE: **COMMERCIAL**
Gal/Day: **1431**
App Rate: **N/A**
Tank Size: **VARIES (SEE SITE PLAN)**
Trench Length: **N/A**
Trench Width: **N/A**
Trench Depth: **N/A**
Total Fees **\$180.00**
Date Received 12/16/11
Receipt # 9690 Ck # 2279

Parcel # 05-30-33-200680

SURVEY: STILLWOOD ESTATES

Vol. 22

Page: 30

Lot # 58

RCRS Properties 12-21-14

CLALLAM COUNTY DEPARTMENT OF COMMUNITY DEVELOPMENT
ENVIRONMENTAL HEALTH DIVISION

SEPTIC SYSTEM INSTALLATION CERTIFICATION AND RECORD DRAWING

TANK PLACEMENT

APPLICANT NAME RCRS PROPERTIES LLC #SEP 2011-00231 Installer C & J EXCAVATING Received 05-08-2013
 PARCEL NUMBER 05-30-33-200580 (Subdivision Lot Blk/Div)
 Date Installed 05-08-2013

Please indicate location of septic tank, pump chamber, drainfield and other system components in relation to the house, property lines, or other permanent objects. Note any change from the approved plans here or on the back of this form.

Scale: 1" = 50'

0 50' 100' 150'

656'±

7,959

RECEIVED
JUN - 3 2013
CLALLAM COUNTY HHS
ENVIRONMENTAL HEALTH DIVISION

DATE: 05/08/2013
 DRAWDOWN: 70 GPM

TIMER SETTINGS:
 ON 1 MIN - 10 SEC NORMAL
 OFF 144 MIN NORMAL
 ON 1 MIN - 10 SEC VETO
 OFF 115 MIN VETO

GAL/DOSE NORMAL: 80
 GAL/DOSE VETO: 80
 GPD NORMAL: 800
 GPD VETO: 1000
 EVENTS: 0
 NUMBER OF DOSES: 0
 NUMBER OF V DOSES: 0
 ETM: 00:06:10 "A" -- 00:13:30 "B"

THE PREVIOUS EXISTING TANKS WERE PUMPED-OUT BY O.M.I. THE TANKS WERE PROPERLY CRUSHED AND FILLED BY C&J EXCAVATING AND ABANDONED IN PLACE.

ON-SITE WASTEWATER TREATMENT SYSTEM
 STATE OF WA
 JERRY L. JACOBS
 LICENSED DESIGNER
 5100126
 EXPIRES 12/29/2014

I personally inspected this On-Site Sewage Disposal System and certify that portions inspected were installed in accordance with the approved design and complies with the conditions noted on the permit and with WAC 246-272A.

Designer of Record JERRY L. JACOBS Date 06/02/2013