

Subject: Fwd: 1400 10th ave letter



Barbara M. Hooker <barbarahooker@bmireo.com>
to Scott Parker, Mike S. Hooker

Wed, Dec 1, 2021, 11:3

You are viewing an attached message. ABG Companies Mail can't verify the authenticity of attached messages.

Hi Scott this needs to be attached to email to county
Thanks

Get [Outlook for iOS](#)

From: Brege, Paul <Paul.Brege@dot.state.fl.us>
Sent: Wednesday, December 1, 2021 9:02 AM
To: Barbara M. Hooker
Subject: RE: 1400 10th ave letter

Hello Mike & Barbara,

Per the site visit that took place yesterday Tuesday November 30, 2021, at the old Russel Concrete existing driveway on US 1. In that discussion no work will be done within the FDOT Right of Way at this time. The one issue that needed to be addressed was the existing gate on the property. Per FDOT requirements the existing gate at that location needs to be relocated to be, a minimum of a 100 Ft. from the ultimate R/W that is considered to the back of sidewalk. Driveway is to be used only by customer traffic. All truck traffic needs to use 10th Ave at main entrance. No permits are needed from the FDOT at this time.

Thanks Again,

Paul Brege
Maintenance Manager – Permits
Off. (772) 429 -4923
Cell. (772) 216 -4263
Fax. (772)429-4812

Treasure Coast Operations
3601 Oleander Ave.
Fort Pierce, Fl. 34982

From: Barbara M. Hooker <barbarahooker@bmireo.com>
Sent: Tuesday, November 30, 2021 2:28 PM